

884883

County Isanti
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 11/06/2025
Received Date 01/24/2025

Well Name WOLLEAT,					Township 34	Range 23	Dir Section W 14	Subsection DAA	Well Depth 172 ft.				Depth Completed 172 ft.				Date Well Completed 11/26/2024			
Elevation					Elev. Method					Drill Method Non-specified Rotary				Drill Fluid Bentonite						
Address									Use domestic				Status Active							
Contact 54 CENTURY TR LINO LAKES MN 55014									Well Hydrofractured? Yes ☐ No ☒ From To											
Well 25536 DURANT ST NE ISANTI MN									Casing Type Single casing Joint Threaded											
Stratigraphy Information									Drive Shoe? Yes ☒ No ☐ Above/Below											
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter														
SAND		0	25	BROWN	SOFT	4 in. To 126 ft. 11 lbs./ft. 8 in. To 50 ft.														
CLAY		25	30	GRAY	SOFT	6.7 in. To 126 ft.														
CLAY		30	46	BROWN	SOFT	3.9 in. To 172 ft.														
SAND		46	54	BROWN	SOFT															
CLAY, GRAVEL		54	118	BROWN	MEDIUM															
SHALE, SANDSTONE		118	172	VARIED	MEDIUM															
									Open Hole From 126 ft. To 172 ft.											
									Screen? ☐ Type Make											
									Static Water Level											
									5 ft. land surface Measure 11/26/2024											
									Pumping Level (below land surface)											
									40 ft. 1 hrs. Pumping at 100 g.p.m.											
									Wellhead Completion											
									Pitless adapter manufacturer AQUA SEAL Model 4X1											
									☐ Casing Protection ☒ 12 in. above grade											
									☐ At-grade (Environmental Wells and Borings ONLY)											
									Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified											
									Material Amount From To											
									bentonite 4 Sacks ft. 50 ft.											
									Nearest Known Source of Contamination											
									20 feet South Direction Other Type											
									Well disinfected upon completion? ☒ Yes ☐ No											
									Pump ☐ Not Installed Date Installed 01/02/2025											
									Manufacturer's name FLOWISE											
									Model Number P10S05 HP 0.5 Volt 230											
									Length of drop pipe 40 ft Capacity g.p. Typ Submersible											
									Abandoned											
									Does property have any not in use and not sealed well(s)? ☐ Yes ☐ No											
									Variance											
									Was a variance granted from the MDH for this well? ☐ Yes ☒ No											
									Miscellaneous											
									First Bedrock Aquifer											
									Last Strat Depth to Bedrock ft											
									Located by											
									Locate Method											
									System UTM - NAD83, Zone 15, Meters X Y											
									Unique Number Verification Input Date											
									Angled Drill Hole											
									Well Contractor											
									Mork Well Co., Inc. 1877 RICKE, GREG											
									Licensee Business Lic. or Reg. No. Name of Driller											
Remarks																				