

884928

County Douglas
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/03/2025
Update Date 06/03/2025
Received Date 01/16/2025

Well Name HIGH POINT	Township 128	Range 37	Dir Section W 21	Subsection DAC	Well Depth 95 ft.	Depth Completed 85 ft.	Date Well Completed 10/14/2024
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Other	
Address					Use domestic	Status Active	
Well 1216 MAPLE DR SE ALEXANDRIA MN 56308					Well Hydrofractured? Yes ☐ No ☒ From To		
Contact ALEXANDRIA MN 56308					Casing Type Single casing Joint		
Stratigraphy Information					Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter	
TOPSOIL		0	2	BLACK	SOFT	4 in. To 81 ft. lbs./ft. 8 in. To 95 ft.	
CLAY		2	23	BROWN	MEDIUM		
CLAY		23	74	GRAY	HARD		
COARSE SAND		74	85	GRAY	MEDIUM		
SAND CLAY LAYERS		85	95	GRAY	MEDIUM		
					Open Hole From 85 ft. To 95 ft.		
					Screen? ☒ Type telescoping Make JOHNSON		
					Diameter Slot/Gauze Length Set		
					4 in. 20 4 ft. 81 ft. 85 ft.		
					Static Water Level		
					22 ft. land surface Measure 10/14/2024		
					Pumping Level (below land surface)		
					84 ft. 3 hrs. Pumping at 75 g.p.m.		
					Wellhead Completion		
					Pitless adapter manufacturer GRADEAMAASS Model 4J1		
					☐ Casing Protection ☒ 12 in. above grade		
					☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
					Material Amount From To		
					bentonite 6 Sacks ft. 50 ft.		
					Nearest Known Source of Contamination		
					feet Direction Type		
					Well disinfected upon completion? ☒ Yes ☐ No		
					Pump ☐ Not Installed Date Installed 10/31/2024		
					Manufacturer's name GRUNDFOS		
					Model Number 22SQE10- HP 1 Volt 230		
					Length of drop pipe 60 ft Capacity 22 g.p. Typ Submersible		
					Abandoned		
					Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
					Variance		
					Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
					Miscellaneous		
					First Bedrock Aquifer		
					Last Strat Depth to Bedrock ft		
					Located by		
					Locate Method		
					System UTM - NAD83, Zone 15, Meters X Y		
					Unique Number Verification Input Date		
					Angled Drill Hole		
					Well Contractor		
					Steven M Traut Wells, Inc. 1889 RICK, COLE		
					Licensee Business Lic. or Reg. No. Name of Driller		