

884949

County Douglas
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/06/2025
Update Date 06/06/2025
Received Date 02/07/2025

Well Name HIGH POINT	Township 129	Range 38	Dir Section W 24	Subsection CAC	Well Depth 103 ft.	Depth Completed 93 ft.	Date Well Completed 11/01/2024
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Other	
Address					Use domestic	Status Active	
Well 8014 SOUTH PILGRIM POINT LA NW ALEXANDRIA MN					Well Hydrofractured? Yes ☐ No ☒ From To		
Contact ALEXANDRIA MN 56308					Casing Type Single casing Joint		
Stratigraphy Information					Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter	
TOPSOIL		0	2	BLACK	SOFT	4 in. To 85 ft. lbs./ft. 8 in. To 103 ft.	
SAND		2	23	BROWN	MEDIUM		
CLAY		23	27	BROWN	MEDIUM		
SAND CLAY LAYERS		27	54	GRAY	MEDIUM		
SAND		54	93	GRAY	MEDIUM		
CLAY		93	103	GRAY	MEDIUM		
					Open Hole From 93 ft. To 103 ft.		
					Screen? ☒ Type telescoping Make JOHNSON		
					Diameter Slot/Gauze Length Set		
					4 in. 18 8 ft. 85 ft. 93 ft.		
					Static Water Level		
					16 ft. land surface Measure 11/01/2024		
					Pumping Level (below land surface)		
					92 ft. 3 hrs. Pumping at 100 g.p.m.		
					Wellhead Completion		
					Pitless adapter manufacturer GRADEAMAASS Model 4J1.25		
					☐ Casing Protection ☒ 12 in. above grade		
					☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
					Material Amount From To		
					bentonite 7 Sacks ft. 50 ft.		
					Nearest Known Source of Contamination		
					feet Direction Sewer Type		
					Well disinfected upon completion? ☒ Yes ☐ No		
					Pump ☐ Not Installed Date Installed 11/13/2024		
					Manufacturer's name GRUNDFOS		
					Model Number 22SQE10- HP 1 Volt 230		
					Length of drop pipe 40 ft Capacity 22 g.p. Typ Submersible		
					Abandoned		
					Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
					Variance		
					Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
					Miscellaneous		
					First Bedrock Aquifer		
					Last Strat Depth to Bedrock ft		
					Located by		
					Locate Method		
					System UTM - NAD83, Zone 15, Meters X Y		
					Unique Number Verification Input Date		
					Angled Drill Hole		
					Well Contractor		
					Steven M Traut Wells, Inc. 1889 RICK, COLE		
					Licensee Business Lic. or Reg. No. Name of Driller		