

886077

County Becker
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 04/28/2026
Received Date 02/02/2026

Well Name WOTHE,	Township 138	Range 43	Dir W	Section 15	Subsection ADC	Well Depth 68 ft.	Depth Completed 68 ft.	Date Well Completed 11/17/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Well 14846 VICTORY LA LAKE PARK MN 56554						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact FRAZEE MN 56544						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
TOP SOIL		0	2	BLACK	HARD	4 in. To 64 ft. 1.9 lbs./ft. 6.7 in. To 68 ft.		
CLAY		2	18	BROWN	HARD			
GRAVEL		18	23	BROWN	HARD			
CLAY		23	35	BROWN	HARD			
GRAVEL		35	43	BROWN	HARD			
SAND		43	66	BROWN	SOFT			
WATER SAND		66	68	GRAY	SOFT			
Open Hole						From	ft.	To ft.
Screen? ☒						Type stainless		Make JOHNSON
Diameter						Slot/Gauze	Length	Set
4 in.						12	4 ft.	64 ft. 68 ft.
Static Water Level								
45 ft.						land surface	Measure	11/17/2025
Pumping Level (below land surface)								
50 ft.						2 hrs.	Pumping at	35 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						BAKER	Model 4AD	
☐ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material						Amount	From	To
bentonite						3 Sacks	ft.	50 ft.
Nearest Known Source of Contamination								
54 feet						Southeas Direction		Other Type
Well disinfected upon completion?						☒ Yes	☐ No	
Pump ☐ Not Installed						Date Installed		11/17/2025
Manufacturer's name						SCHAEFER		
Model Number						HP	Volt	230
LD105S						0.5		
Length of drop pipe						ft	Capacity	g.p. Typ Submersible
50						10		
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No		
Variance								
Was a variance granted from the MDH for this well?						☐ Yes ☒ No		
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock ft		
Located by								
Locate Method								
System						UTM - NAD83, Zone 15, Meters	X	Y
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Cormorant Well And Pump						1498	VAREBERG, S.	
Licensee Business						Lic. or Reg. No.	Name of Driller	