

886164

County Marshall
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 01/16/2025
Update Date 01/16/2025
Received Date 10/02/2024

Well Name BLAZEJEWSKI,					Township 157	Range 46	Dir W	Section 14	Subsection AAD	Well Depth 82 ft.		Depth Completed 82 ft.		Date Well Completed 10/22/2024													
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Bentonite															
Address										Use domestic		Status Active															
C/W 38005 PEMBIA TR NW STRANDQUIST MN 56758										Well Hydrofractured?		Yes ☐ No ☒		From To													
Stratigraphy Information										Casing Type Single casing		Joint															
										Drive Shoe?		Yes ☐ No ☒		Above/Below													
Geological Material										From		To (ft.)		Color		Hardness											
TOP SOIL										0		2		BLACK		SOFT											
SAND										2		15		TAN		SOFT											
CLAY										15		76		GRAY		MEDIUM											
SAND										76		82		GRAY		SOFT											
										Open Hole		From		ft.		To		ft.									
										Screen? ☒		Type stainless		Make JOHNSON													
										Diameter		Slot/Gauze		Length		Set											
										4 in.		6		4 ft.		78 ft.		82 ft.									
										Static Water Level																	
										10 ft.		land surface				Measure		10/22/2024									
										Pumping Level (below land surface)																	
										82 ft.		3 hrs.		Pumping at				25 g.p.m.									
										Wellhead Completion																	
										Pitless adapter manufacturer				AQUA SEAL				Model									
										☐ Casing Protection				☒ 12 in. above grade													
										☐ At-grade (Environmental Wells and Borings ONLY)																	
										Grouting Information										Well Grouted? ☒ Yes ☐ No ☐ Not Specified							
										Material				Amount				From		To							
										other				5 Sacks						ft. 60		ft.					
										Nearest Known Source of Contamination																	
										60 feet				South Direction				Septic tank/drain field Type									
										Well disinfected upon completion? ☒ Yes ☐ No																	
										Pump ☐ Not Installed										Date Installed							
										Manufacturer's name										STARITE							
										Model Number				3WIRE		HP 1		Volt 240									
										Length of drop pipe				ft		Capacity 20		g.p.		Typ Submersible							
										Abandoned																	
										Does property have any not in use and not sealed well(s)?										☐ Yes ☒ No							
										Variance																	
										Was a variance granted from the MDH for this well?										☐ Yes ☒ No							
										Miscellaneous																	
										First Bedrock				Aquifer													
										Last Strat				Depth to Bedrock				ft									
										Located by																	
										Locate Method																	
										System				UTM - NAD83, Zone 15, Meters				X		Y							
										Unique Number Verification										Input Date							
										Angled Drill Hole																	
										Well Contractor																	
										Leader Well Drilling				3798				LEADER, JON									
										Licensee Business				Lic. or Reg. No.				Name of Driller									