

886493

County Scott
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/05/2026
Update Date 05/05/2026
Received Date 01/15/2026

Well Name KREUSER					Township 113	Range 23	Dir Section W 20	Subsection BCC	Well Depth 190 ft.				Depth Completed 190 ft.				Date Well Completed 09/25/2025			
Elevation					Elev. Method					Drill Method Non-specified Rotary				Drill Fluid Qwik gel						
Address									Use domestic				Status Active							
Contact 301 270TH ST W NEW PRAGUE MN 56071									Well Hydrofractured? Yes ☐ No ☒								From		To	
Well 25341 DELMAR AV NEW PRAGUE MN 56071									Casing Type Single casing				Joint Welded							
Stratigraphy Information									Drive Shoe? Yes ☒ No ☐								Above/Below			
Geological Material					From	To (ft.)	Color	Hardness	Casing Diameter				Weight				Hole Diameter			
CLAY					0	17	YELLOW	MEDIUM	4 in. To 180 ft. 11 lbs./ft.				6.5 in. To 180 ft.							
CLAY					17	85	GRAY	MEDIUM					4 in. To 190 ft.							
CLAY SAND					85	180	GRAY	MED-HRD												
LIME					180	190	GRAY	HARD												
									Open Hole From 180 ft. To 190 ft.											
									Screen? ☐				Type				Make			
									Static Water Level 120 ft. land surface Measure 09/25/2025											
									Pumping Level (below land surface) 120 ft. 2 hrs. Pumping at 30 g.p.m.											
									Wellhead Completion Pitless adapter manufacturer MONITOR Model THREAD ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)											
									Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 8 Sacks ft. 180 ft.											
									Nearest Known Source of Contamination 80 feet Northeast Direction Septic tank/drain field Type Well disinfected upon completion? ☒ Yes ☐ No											
									Pump ☐ Not Installed Date Installed 09/25/2025 Manufacturer's name F+W Model Number S3 100 HP 1 Volt 230 Length of drop pipe 147 ft Capacity 12 g.p. Typ Submersible											
									Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No											
									Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No											
Remarks									Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date											
									Angled Drill Hole											
									Well Contractor Jaeckels Well Service, Inc. 1601 JAECKELS, T Licensee Business Lic. or Reg. No. Name of Driller											

Minnesota Well Index Report

886493

Printed on 10/02/2026
HE-01205-15