

886996

County Douglas
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 06/11/2025
Update Date 06/11/2025
Received Date 12/10/2024

Well Name POTTHOFF, JEFF					Township 130	Range 38	Dir W	Section 25	Subsection CDC																
Elevation					Elev. Method																				
Address																									
Contact					5493 GARDEN HILLS LA ST AUGUSTA MN 56301																				
Well					13716 SCHUELKE BEACH RD NW MILTONA MN 56354																				
Stratigraphy Information																									
Geological Material		From	To (ft.)	Color	Hardness																				
TOPSOIL		0	1	BLACK																					
CLAY		1	50	YELLOW	HARD																				
CLAY		50	70	BLUE	HARD																				
SAND		70	85	BROWN																					
SAND		85	120	GRAY																					
Well Depth 120 ft.																									
Depth Completed 116 ft.																									
Date Well Completed 11/05/2024																									
Drill Method Non-specified Rotary					Drill Fluid Qwik gel																				
Use domestic					Status Active																				
Well Hydrofractured? Yes ☐ No ☐ From To																									
Casing Type Single casing					Joint																				
Drive Shoe? Yes ☐ No ☐					Above/Below																				
Open Hole <table><tr><td>From</td><td>ft.</td><td>To</td><td>ft.</td></tr><tr><td>Screen? ☒</td><td>Type stainless</td><td>Make JOHNSON</td><td></td></tr><tr><td>Diameter 3 in.</td><td>Slot/Gauze 12</td><td>Length 5 ft.</td><td>Set 111 ft.</td></tr><tr><td></td><td></td><td></td><td>116 ft.</td></tr></table>										From	ft.	To	ft.	Screen? ☒	Type stainless	Make JOHNSON		Diameter 3 in.	Slot/Gauze 12	Length 5 ft.	Set 111 ft.				116 ft.
From	ft.	To	ft.																						
Screen? ☒	Type stainless	Make JOHNSON																							
Diameter 3 in.	Slot/Gauze 12	Length 5 ft.	Set 111 ft.																						
			116 ft.																						
Static Water Level 46 ft. land surface Measure 11/05/2024																									
Pumping Level (below land surface) ft. hrs. Pumping at 100 g.p.m.																									
Wellhead Completion Pitless adapter manufacturer MONITOR Model BULLDOG ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																									
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material bentonite Amount From To ft. 60 ft.																									
Nearest Known Source of Contamination 53 feet South Direction Septic tank/drain field Type Well disinfected upon completion? ☐ Yes ☐ No																									
Pump ☐ Not Installed Date Installed 11/05/2024 Manufacturer's name STARITE Model Number HP 0.5 Volt 230 Length of drop pipe 60 ft Capacity 10 g.p. Typ Submersible																									
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																									
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																									
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date																									
Angled Drill Hole																									
Well Contractor Twin Ports Testing, Inc. 1381 JUNTE, DAVE. Licensee Business Lic. or Reg. No. Name of Driller																									
Remarks HARDNESS 85-120: "10-15 SLOT"																									

Minnesota Well Index Report

886996

Printed on 08/13/2026
HE-01205-15