

887059

County Benton
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 03/28/2025
Update Date 03/28/2025
Received Date 12/31/2024

Well Name DAVIS, MIKE	Township 38	Range 28	Dir Section W 18	Subsection BBC																				
Elevation	Elev. Method																							
Address Well 14806 135TH AV NE FOLEY MN 56329 Contact 224 SUNDANCE RD SARTELL MN 56377																								
Stratigraphy Information <table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>CLAY</td><td>0</td><td>23</td><td>BROWN</td><td>HARD</td></tr><tr><td>CLAY</td><td>23</td><td>50</td><td>GRAY</td><td>HARD</td></tr><tr><td>SAND</td><td>50</td><td>58</td><td>BROWN</td><td>SOFT</td></tr></table>					Geological Material	From	To (ft.)	Color	Hardness	CLAY	0	23	BROWN	HARD	CLAY	23	50	GRAY	HARD	SAND	50	58	BROWN	SOFT
Geological Material	From	To (ft.)	Color	Hardness																				
CLAY	0	23	BROWN	HARD																				
CLAY	23	50	GRAY	HARD																				
SAND	50	58	BROWN	SOFT																				
Well Depth 58 ft. Depth Completed 58 ft. Date Well Completed 11/11/2024																								
Drill Method Non-specified Rotary Drill Fluid Bentonite																								
Use domestic Status Active																								
Well Hydrofractured? Yes ☐ No ☐ From To																								
Casing Type Single casing Joint																								
Drive Shoe? Yes ☐ No ☐ Above/Below																								
Casing Diameter Weight 4 in. To 54 ft. lbs./ft.																								
Open Hole From ft. To ft.																								
Screen? ☒ Type stainless Make JOHNSON Diameter Slot/Gauze Length Set 4 in. 20 4 ft. 54 ft. 58 ft. 0 in. ft. ft. ft.																								
Static Water Level 15 ft. land surface Measure 11/11/2024																								
Pumping Level (below land surface) ft. 1 hrs. Pumping at 50 g.p.m.																								
Wellhead Completion Pitless adapter manufacturer Model ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																								
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To driven casing seal 4 Sacks ft. 48 ft.																								
Nearest Known Source of Contamination 65 feet East Direction Septic tank/drain field Type Well disinfected upon completion? ☒ Yes ☐ No																								
Pump ☐ Not Installed Date Installed 11/11/2024 Manufacturer's name AY MCDONALD Model Number HP 0.5 Volt 230 Length of drop pipe 30 ft Capacity 10 g.p. Typ Submersible																								
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																								
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																								
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date																								
Angled Drill Hole																								
Well Contractor GM Drilling, Inc. 1921 MAJENUS, S&J Licensee Business Lic. or Reg. No. Name of Driller																								