

887193

County Pine
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 07/09/2025
Update Date 07/09/2025
Received Date 12/17/2024

Well Name KRZENSKI,					Township 53	Range 19	Dir Section W 11	Subsection ABA	Well Depth 95 ft.		Depth Completed 95 ft.		Date Well Completed 11/28/2024																			
Elevation					Elev. Method					Drill Method Multiple methods used		Drill Fluid																				
Address									Use domestic		Status Active																					
C/W 42230 ROOT RD ASKOV MN 55704									Well Hydrofractured? Yes ☐ No ☒		From		To																			
Stratigraphy Information <table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>SAND CLAY</td><td>0</td><td>20</td><td></td><td></td></tr><tr><td>BROKEN ROCK/ CLAY</td><td>20</td><td>60</td><td></td><td></td></tr><tr><td>SANDSTONE</td><td>60</td><td>95</td><td></td><td></td></tr></table>									Geological Material	From	To (ft.)	Color	Hardness	SAND CLAY	0	20			BROKEN ROCK/ CLAY	20	60			SANDSTONE	60	95			Casing Type Single casing		Joint Welded	
									Geological Material	From	To (ft.)	Color	Hardness																			
									SAND CLAY	0	20																					
									BROKEN ROCK/ CLAY	20	60																					
									SANDSTONE	60	95																					
									Drive Shoe? Yes ☒ No ☐		Above/Below																					
									Casing Diameter 6 in. To 60 ft. 19 lbs./ft.		Hole Diameter 6 in. To 95 ft.																					
									Open Hole From 60 ft. To 95 ft.																							
									Screen? ☐		Type Make																					
									Static Water Level 55 ft. land surface Measure 11/28/2024																							
Pumping Level (below land surface) 85 ft. 1 hrs. Pumping at 20 g.p.m.																																
Wellhead Completion Pitless adapter manufacturer SNAPPY Model 6X1 ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																																
Grouting Information Well Grouted? ☐ Yes ☐ No ☐ Not Specified																																
Nearest Known Source of Contamination <u>100</u> feet Direction Type Well disinfected upon completion? ☒ Yes ☐ No																																
Pump ☐ Not Installed Date Installed <u>11/28/2024</u> Manufacturer's name FPS Model Number HP <u>0.5</u> Volt <u>220</u> Length of drop pipe ft Capacity <u>10</u> g.p. Typ <u>Submersible</u>																																
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																																
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																																
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date																																
Angled Drill Hole																																
Well Contractor Bob Kent Well Drilling 1886 KENT, BOB Licensee Business Lic. or Reg. No. Name of Driller																																