

887279

County Cass
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/29/2025
Received Date 12/26/2024

Well Name KLEIN, KEN &					Township 139	Range 26	Dir W	Section 23	Subsection CBD	Well Depth 130 ft.		Depth Completed 130 ft.		Date Well Completed 10/01/2024					
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Additive (+ Bentonite)							
Address										Use domestic		Status Active							
Well 926 6 SH OUTING MN 56662										Well Hydrofractured? Yes ☐ No ☒		From To							
Contact 8963 REGENT PK BROOKLYN PARK MN 55443										Casing Type Single casing		Joint							
Stratigraphy Information										Drive Shoe? Yes ☐ No ☒		Above/Below							
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter		Weight		Hole Diameter									
TOP SOIL		0	1	BLACK	SOFT	4 in. To		125 ft.		lbs./ft.		7.8 in. To		130 ft.					
ROCKY CLAY		1	12	BROWN	HARD														
FINE ROCKY SAND		12	36	BROWN	MED-HRD														
ROCKY CLAY GRAVEL		36	88	GRAY	HARD														
CLAY SAND		88	92	GRAY	SOFT														
ROCKY CLAY GRAVEL		92	124	GRAY	HARD														
										Open Hole		From		ft.		To		ft.	
										Screen? ☒		Type stainless		Make JOHNSON					
										Diameter		Slot/Gauze		Length		Set			
										3 in.		12		5 ft.		125 ft.		130 ft.	
										Static Water Level		26 ft.		land surface		Measure		10/01/2024	
										Pumping Level (below land surface)		ft.		hrs.		Pumping at		g.p.m.	
										Wellhead Completion		Pitless adapter manufacturer		SIMMON		Model		SPK4X1	
										☐ Casing Protection		☒ 12 in. above grade							
										☐ At-grade (Environmental Wells and Borings ONLY)									
										Grouting Information		Well Grouted? ☒ Yes ☐ No ☐ Not Specified							
										Material		Amount		From		To			
										other				50		ft. 130		ft.	
										bentonite		4 Sacks				ft. 50		ft.	
										Nearest Known Source of Contamination		60 feet		South Direction		Septic tank/drain field		Type	
										Well disinfected upon completion?		☒ Yes ☐ No							
										Pump ☐ Not Installed		Date Installed		10/01/2024					
										Manufacturer's name		GOULDS							
										Model Number		10505		HP 0.5		Volt 230			
										Length of drop pipe		90 ft		Capacity 12		g.p.		Typ Submersible	
										Abandoned		Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No					
										Variance		Was a variance granted from the MDH for this well?		☐ Yes ☒ No					
										Miscellaneous		First Bedrock		Aquifer					
										Last Strat				Depth to Bedrock				ft	
										Located by									
										Locate Method									
										System		UTM - NAD83, Zone 15, Meters		X		Y			
										Unique Number Verification						Input Date			
										Angled Drill Hole									
										Well Contractor		Runyan Well Drilling		1903		DAN & JOSH			
										Licensee Business				Lic. or Reg. No.		Name of Driller			