

888044

County Becker
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/28/2026
Received Date 11/12/2025

Well Name WEAVER, LUKE	Township 138	Range 43	Dir W	Section 3	Subsection BAB
Elevation	Elev. Method				
Address					
Well 14171 6 CH LAKE PARK MN 56554					
Contact 16555 87 SH PARK RAPIDS MN 56470					
Stratigraphy Information					
Geological Material		From	To (ft.)	Color	Hardness
SANDY CLAY		0	42	BROWN	HARD
SANDY CLAY		42	189	GRAY	HARD
SAND		189	196	GRAY	SOFT
Well Depth 196 ft.					
Depth Completed 196 ft.					
Date Well Completed 10/24/2025					
Drill Method Non-specified Rotary					
Drill Fluid Bentonite					
Use domestic					
Status Active					
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing Type Single casing					
Joint					
Drive Shoe? Yes ☐ No ☒ Above/Below					
Casing Diameter Weight Hole Diameter					
4 in. To 192 ft. 1.9 lbs./ft. 6.5 in. To 196 ft.					
Open Hole From ft. To ft.					
Screen? ☒ Type telescoping Make JOHNSON					
Diameter Slot/Gauze Length Set					
4 in. 15 4 ft. 192 ft. 196 ft.					
Static Water Level					
90 ft. land surface Measure 10/02/2025					
Pumping Level (below land surface)					
196 ft. 1 hrs. Pumping at 50 g.p.m.					
Wellhead Completion					
Pitless adapter manufacturer BAKER Model 4AD					
☐ Casing Protection ☒ 12 in. above grade					
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material Amount From To					
bentonite 4 Sacks ft. 50 ft.					
Nearest Known Source of Contamination					
70 feet East Direction Other Type					
Well disinfected upon completion? ☒ Yes ☐ No					
Pump ☐ Not Installed Date Installed 10/24/2025					
Manufacturer's name GRUNDFOS					
Model Number 10SQ07200 HP 0.75 Volt 230					
Length of drop pipe 120 ft Capacity 10 g.p. Typ Submersible					
Abandoned					
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First Bedrock Aquifer					
Last Strat Depth to Bedrock ft					
Located by					
Locate Method					
System UTM - NAD83, Zone 15, Meters X Y					
Unique Number Verification Input Date					
Angled Drill Hole					
Well Contractor					
Krueger Water Wells, Inc. 2132 KRAFT, C.					
Licensee Business Lic. or Reg. No. Name of Driller					