

888048

County Clay
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/09/2026
Received Date 11/12/2025

Well Name PARROW,	Township 140	Range 46	Dir Section W 34	Subsection CCB	Well Depth 124 ft.	Depth Completed 124 ft.	Date Well Completed 10/27/2025
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address					Use domestic	Status Active	
Well 1648 170TH ST N GLYNDON MN 56547					Well Hydrofractured? Yes ☐ No ☒ From To		
Contact 4015 47TH ST N FARGO ND 58102					Casing Type Single casing Joint		
Stratigraphy Information					Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter	
SANDY CLAY		0	15	BROWN	SOFT	4 in. To 116 ft. 1.9 lbs./ft. 6.5 in. To 124 ft.	
SILTY CLAY		15	92	GRAY	SOFT		
VERY FINE SAND		92	96	GRAY	SOFT		
SILTY CLAY		96	107	GRAY	SOFT		
SAND		107	124	GRAY	SOFT		
					Open Hole From ft. To ft.		
					Screen? ☒ Type stainless Make JOHNSON		
					Diameter Slot/Gauze Length Set		
					4 in. 12 8 ft. 116 ft. 124 ft.		
					Static Water Level		
					3 ft. land surface Measure 10/27/2025		
					Pumping Level (below land surface)		
					124 ft. 1 hrs. Pumping at 30 g.p.m.		
					Wellhead Completion		
					Pitless adapter manufacturer BAKER Model 4A0		
					☐ Casing Protection ☒ 12 in. above grade		
					☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
					Material Amount From To		
					bentonite 2 ft. 50 ft.		
					Nearest Known Source of Contamination		
					40 feet East Direction Other Type		
					Well disinfected upon completion? ☒ Yes ☐ No		
					Pump ☐ Not Installed Date Installed 10/27/2025		
					Manufacturer's name GRUNDFOS		
					Model Number 10SQ07200 HP 0.75 Volt 230		
					Length of drop pipe 40 ft Capacity 10 g.p. Typ Submersible		
					Abandoned		
					Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
					Variance		
					Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
					Miscellaneous		
					First Bedrock Aquifer		
					Last Strat Depth to Bedrock ft		
					Located by		
					Locate Method		
					System UTM - NAD83, Zone 15, Meters X Y		
					Unique Number Verification Input Date		
					Angled Drill Hole		
					Well Contractor		
					Krueger Water Wells, Inc. 2132 KRAFT, C		
					Licensee Business Lic. or Reg. No. Name of Driller		