

888623

County St. Louis
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/03/2026
Update Date 04/03/2026
Received Date 10/27/2025

Well Name STEWART, TOM	Township 53	Range 16	Dir W	Section 6	Subsection ACD																														
Elevation Elev. Method																																			
Address Well 8249 E ROSE LAKE DR CANYON MN Contact 14805 SUMMIT OAKS DR BURNSVILLE MN 55337																																			
Stratigraphy Information <table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>SAND</td><td>0</td><td>35</td><td>BROWN</td><td>SOFT</td></tr><tr><td>CLAY</td><td>35</td><td>60</td><td>BROWN</td><td>MEDIUM</td></tr><tr><td>CEMENTED SAND +</td><td>60</td><td>80</td><td>BROWN</td><td>HARD</td></tr><tr><td>CEMENTED SAND +</td><td>80</td><td>112</td><td>GRAY</td><td>HARD</td></tr><tr><td>SAND/ GRAVEL</td><td>112</td><td>114</td><td>BLACK</td><td>MEDIUM</td></tr></table>						Geological Material	From	To (ft.)	Color	Hardness	SAND	0	35	BROWN	SOFT	CLAY	35	60	BROWN	MEDIUM	CEMENTED SAND +	60	80	BROWN	HARD	CEMENTED SAND +	80	112	GRAY	HARD	SAND/ GRAVEL	112	114	BLACK	MEDIUM
Geological Material	From	To (ft.)	Color	Hardness																															
SAND	0	35	BROWN	SOFT																															
CLAY	35	60	BROWN	MEDIUM																															
CEMENTED SAND +	60	80	BROWN	HARD																															
CEMENTED SAND +	80	112	GRAY	HARD																															
SAND/ GRAVEL	112	114	BLACK	MEDIUM																															
Well Depth 114 ft.						Depth Completed 114 ft.	Date Well Completed 10/10/2025																												
Drill Method Dual Rotary		Drill Fluid Water																																	
Use domestic				Status Active																															
Well Hydrofractured? Yes ☐ No ☒ From To																																			
Casing Type Single casing Joint																																			
Drive Shoe? Yes ☒ No ☐ Above/Below																																			
Casing Diameter 6 in. To 114 ft. 19.45 lbs./ft.																																			
Open Hole From ft. To ft.																																			
Screen? ☐ Type Make																																			
Static Water Level 15 ft. land surface Measure 09/30/2025																																			
Pumping Level (below land surface) 24 ft. 4 hrs. Pumping at 20 g.p.m.																																			
Wellhead Completion Pitless adapter manufacturer BULLDOG Model 6X1 ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)																																			
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 6 Sacks ft. 114 ft.																																			
Nearest Known Source of Contamination 68 feet North Direction Sewer Type Well disinfected upon completion? ☐ Yes ☐ No																																			
Pump ☐ Not Installed Date Installed 09/30/2025 Manufacturer's name GRUNDFOS Model Number 15SQE1022 HP 1 Volt 250 Length of drop pipe 60 ft Capacity 10 g.p. Typ Submersible																																			
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																																			
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No																																			
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date																																			
Angled Drill Hole																																			
Well Contractor Petersen Well Drilling, Inc. 2139 DAN Licensee Business Lic. or Reg. No. Name of Driller																																			