

888763

County Todd
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/28/2025
Received Date 01/16/2025

Well Name WHALLEN, JAKE 128					Township 33		Range W 20		Dir Section DDC	
Elevation					Elev. Method					
Address C/W 24908 170TH ST LONG PRAIRIE MN										
Stratigraphy Information										
Geological Material		From	To (ft.)	Color	Hardness					
TOP SOIL		0	2	BLACK	SOFT					
SAND\CLAY LAYERS		2	42	BROWN	MEDIUM					
CLAY		42	62	BROWN	MEDIUM					
CLAY		62	93	GRAY	HARD					
COARSE SAND		93	122	GRAY	MEDIUM					
MUSHY CLAY		122	132	GRAY	SOFT					
Well Depth 132 ft.					Depth Completed 122 ft.			Date Well Completed 11/26/2024		
Drill Method Non-specified Rotary					Drill Fluid Other					
Use domestic					Status Active					
Well Hydrofractured? Yes ☐ No ☒					From To					
Casing Type Single casing					Joint					
Drive Shoe? Yes ☐ No ☒					Above/Below					
Casing Diameter 4 in. To 114 ft.					Weight lbs./ft.			Hole Diameter 8 in. To 132 ft.		
Open Hole From ft. To ft.										
Screen? ☒					Type telescoping			Make JOHNSON		
Diameter		Slot/Gauze	Length	Set						
4 in.		20	8 ft.	114 ft.	122 ft.					
Static Water Level 33 ft. land surface Measure 11/25/2024										
Pumping Level (below land surface) 120 ft. 3 hrs. Pumping at 100 g.p.m.										
Wellhead Completion Pitless adapter manufacturer GRADE AMAASS Model 4J1 ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)										
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 6 Sacks ft. 50 ft.										
Nearest Known Source of Contamination feet Direction Type Well disinfected upon completion? ☒ Yes ☐ No										
Pump ☐ Not Installed Date Installed 11/27/2024 Manufacturer's name GRUNDFOS Model Number 22SQE1099 HP 1 Volt 230 Length of drop pipe 60 ft Capacity 22 g.p. Typ Submersible										
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No										
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No										
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date										
Angled Drill Hole										
Well Contractor Steven M Traut Wells, Inc. 1889 RICK, C Licensee Business Lic. or Reg. No. Name of Driller										

Remarks
GRAVEL PACKED
T+C 12-20-24