

888768

County Douglas
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/05/2026
Received Date 08/06/2025

Well Name HAABALA	Township 129	Range 38	Dir W	Section 26	Subsection BDA	Well Depth 108 ft.	Depth Completed 98 ft.	Date Well Completed 01/08/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid	Other
Address						Use domestic	Status Active	
Well 6185 BEDMAN DR ALEXANDRIA MN 56308						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact ALEXANDRIA MN 56308						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
FILL		0	2	BROWN	SOFT	4 in. To 94 ft. lbs./ft. 8 in. To 108 ft.		
SAND		2	39	BROWN	MEDIUM			
SANDY CLAY		39	62	BROWN	MEDIUM			
CLAY		62	94	GRAY	HARD			
COARSE SAND		94	98	GRAY	MEDIUM			
CLAY		98	108	GRAY	HARD			
Open Hole						From	ft.	To ft.
Screen? ☒						Type telescoping	Make JOHNSON	
Diameter		Slot/Gauze	Length	Set				
4 in.		20	4 ft.	94 ft.		98 ft.		
Static Water Level								
39 ft.		land surface		Measure		01/08/2025		
Pumping Level (below land surface)								
97 ft.		3 hrs.	Pumping at		50	g.p.m.		
Wellhead Completion								
Pitless adapter manufacturer		GRADEAMAASS		Model		4J1.25		
☐ Casing Protection		☒ 12 in. above grade						
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material		Amount		From		To		
bentonite		8 Sacks		ft.		50 ft.		
Nearest Known Source of Contamination								
feet		Direction				Type		
Well disinfected upon completion?						☒ Yes ☐ No		
Pump ☐ Not Installed						Date Installed	07/29/2025	
Manufacturer's name GRUNDFOS								
Model Number		HP	1	Volt		230		
Length of drop pipe		ft	Capacity	g.p.	Typ	Submersible		
70		ft	22	g.p.	Typ	Submersible		
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No		
Variance								
Was a variance granted from the MDH for this well?						☐ Yes ☒ No		
Miscellaneous								
First Bedrock		Aquifer						
Last Strat		Depth to Bedrock		ft				
Located by								
Locate Method								
System		UTM - NAD83, Zone 15, Meters		X		Y		
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Steven M Traut Wells, Inc.		1889		RICK, C.				
Licensee Business		Lic. or Reg. No.		Name of Driller				