

888811

County Beltrami
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 07/30/2025
Update Date 07/31/2025
Received Date 06/03/2025

Well Name MCKERCHER,	Township 148	Range 32	Dir W	Section 33	Subsection ABB	Well Depth 68 ft.	Depth Completed 68 ft.	Date Well Completed 06/22/2025
Elevation						Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Elev. Method						Use domestic	Status Active	
Address						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact 397 BRIGHT AV NE TURTLE RIVER MN 56601						Casing Type Single casing Joint		
Well 501 MAIN AV E BEMIDJI MN 56601						Drive Shoe? Yes ☐ No ☒ Above/Below		
Stratigraphy Information						Casing Diameter Weight Hole Diameter		
Geological Material		From	To (ft.)	Color	Hardness	4 in. To 63 ft. 21 lbs./ft. 8 in. To 68 ft.		
SAND		0	12	BROWN	SOFT			
CLAY		12	62	GRAY	MEDIUM			
SAND		62	68	GRAY	SOFT			
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						2 in. 10 5 ft. 63 ft. 68 ft.		
						Static Water Level		
						15 ft. land surface Measure 06/22/2025		
						Pumping Level (below land surface)		
						60 ft. 2 hrs. Pumping at 20 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer MONITOR Model SNAPPY		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						bentonite 4 Sacks ft. 50 ft.		
						Nearest Known Source of Contamination		
						60 feet West Direction Septic tank/drain field Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 06/22/2025		
						Manufacturer's name GRUNDFOS		
						Model Number 10S007-200 HP 0.75 Volt 230		
						Length of drop pipe 50 ft Capacity 10 g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Antlers Well Drilling 1448 PINK, CHRIS		
						Licensee Business Lic. or Reg. No. Name of Driller		