

888845

County Traverse
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/11/2026
Update Date 05/11/2026
Received Date 12/16/2025

Well Name ANDERSON,	Township 125	Range 49	Dir W	Section 2	Subsection CCA	Well Depth 48 ft.	Depth Completed 48 ft.	Date Well Completed 11/20/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Contact 401 3RD AV S FAIRMONT MN 58030						Well Hydrofractured? Yes ☐ No ☐ From To		
Well 5208 WATERFRONT DR BROWNS VALLEY MN 56219						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
TOP SOIL		0	1	BLACK	MEDIUM	3 in. To 42 ft. 2 lbs./ft. 7 in. To 48 ft.		
CLAY		1	22	YELLOW	MEDIUM			
CLAY		22	35	GRAY	HARD			
SAND		35	48	GRY/BRN	MEDIUM			
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						2.5 in. 15 6 ft. ft. ft.		
						Static Water Level		
						10 ft. land surface Measure 11/20/2025		
						Pumping Level (below land surface)		
						25 ft. 2 hrs. Pumping at 15 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer MONITOR Model BULLDOG		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						bentonite 5 Sacks ft. 35 ft.		
						Nearest Known Source of Contamination		
						75 feet South Direction Septic tank/drain field Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 11/20/2025		
						Manufacturer's name GRUNFOS		
						Model Number 10SQ 3" HP 0.5 Volt 115		
						Length of drop pipe 40 ft Capacity 10 g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Reinart Bros. Well Drilling, 1826 REINART, G		
						Licensee Business Lic. or Reg. No. Name of Driller		