

889158

County Wright
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/04/2026
Update Date 05/04/2026
Received Date 01/12/2026

Well Name SWANSON,	Township 121	Range 27	Dir W	Section 22	Subsection CDC	Well Depth 50 ft.	Depth Completed 50 ft.	Date Well Completed 12/03/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid	Other
Address						Use domestic	Status Active	
Contact 16883 CEDAR CREST DR EDEN PRAIRIE MN 55347						Well Hydrofractured? Yes ☐ No ☐ From To		
Well 7992 IRVINE AV NW ANNANDALE MN						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material From To (ft.) Color Hardness						Casing Diameter Weight		
SAND/ GRAVEL 0 21 BROWN MEDIUM						4 in. To 42 ft. lbs./ft.		
CLAY 21 36 GRAY MEDIUM								
SAND 36 50 BROWN MEDIUM								
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						2 in. 10 8 ft. 42 ft. 50 ft.		
						Static Water Level		
						15 ft. land surface Measure 12/03/2025		
						Pumping Level (below land surface)		
						48 ft. 1 hrs. Pumping at 30 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer MONITOR Model SNAPPY		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						bentonite 6 Sacks ft. 42 ft.		
						Nearest Known Source of Contamination		
						50 feet North Direction Septic tank/drain field Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 12/03/2025		
						Manufacturer's name STA-RITE		
						Model Number HP 0.75 Volt 230		
						Length of drop pipe 25 ft Capacity 10 g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Fobbe Well, LLP 1919 FOBBE, R		
						Licensee Business Lic. or Reg. No. Name of Driller		
Remarks								