

890334

County Stevens

Quad

Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date

05/04/2026

Update Date

05/04/2026

Received Date

01/21/2026

Well Name THORSTAD,	Township 125	Range 42	Dir W	Section 16	Subsection CDA	Well Depth 133 ft.	Depth Completed 133 ft.	Date Well Completed 09/22/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
C/W 18960 9 SH MORRIS MN 56267						Well Hydrofractured?	Yes ☐	No ☐
Stratigraphy Information						From	To	Joint
Geological Material	From	To (ft.)	Color	Hardness				
TOPSOIL	0	1	BLACK					
CLAY	1	9	YELLOW					
CLAY	9	121	BLUE					
SAND	121	133	GRAY					
Drive Shoe?						Yes ☐	No ☐	Above/Below
Casing Type Single casing						Joint		
Casing Diameter						Weight	Hole Diameter	
4 in. To						128 ft.	lbs./ft.	6.5 in. To 133 ft.
Open Hole						From	ft.	To
Screen? ☒						Type telescoping	Make JOHNSON	
Diameter						Slot/Gauze	Length	Set
4 in.						12	5 ft.	128 ft. 133 ft.
Static Water Level								
48 ft.						land surface	Measure	09/22/2025
Pumping Level (below land surface)								
50 ft.						1 hrs.	Pumping at	12 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						Model		
☐ Casing Protection						☐ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒	Yes ☐	No ☐
Material						Amount	From	To
cuttings							60 ft.	120 ft.
high solids bentonite						5 Sacks	ft. 60	ft.
Nearest Known Source of Contamination								
70 feet						West Direction	Septic tank/drain field Type	
Well disinfected upon completion?						☒	Yes	No ☐
Pump ☒						Not Installed	Date Installed	
Manufacturer's name								
Model Number						HP	Volt	
Length of drop pipe						ft	Capacity	g.p. Typ
Abandoned								
Does property have any not in use and not sealed well(s)?						☐	Yes	No ☐
Variance								
Was a variance granted from the MDH for this well?						☐	Yes	No ☒
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock		
Located by								
Locate Method								
System UTM - NAD83, Zone 15, Meters						X	Y	
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
Steffl Drilling and Pump, Inc.						1551	JONES, W	
Licensee Business						Lic. or Reg. No.	Name of Driller	