

890348

County Redwood
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/07/2026
Received Date 01/21/2026

Well Name DAHES LEGACY					Township 111	Range 35	Dir W	Section 30	Subsection DAD	Well Depth 98 ft.		Depth Completed 66 ft.		Date Well Completed 11/06/2025			
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Bentonite					
Address										Use domestic		Status Active					
C/W 23288 MIDWAY AV CLEMENTS MN 56224										Well Hydrofractured? Yes ☐ No ☒ From To							
Stratigraphy Information										Casing Type Single casing		Joint					
										Drive Shoe? Yes ☐ No ☐		Above/Below					
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter		Weight		Hole Diameter							
TOPSOIL		0	1	BLACK		6 in. To		61 ft. lbs./ft.		7.9 in. To		66 ft.					
CLAY		1	17	YELLOW	MEDIUM												
CLAY		17	61	BLUE	MEDIUM												
SAND/ GRAVEL -		61	66	BLUE	MEDIUM												
CLAY		66	84	DK. GRY	MED-HRD												
DECOMPOSED		84	98	WHITE													
										Open Hole		From	ft.	To	ft.		
										Screen? ☒		Type telescoping		Make JOHNSON			
										Diameter		Slot/Gauze		Length		Set	
										4 in.		18		4 ft.		62 ft. 66 ft.	
										Static Water Level							
										15 ft.		land surface		Measure		11/07/2025	
										Pumping Level (below land surface)							
										18 ft.		hrs.		Pumping at		15 g.p.m.	
										Wellhead Completion							
										Pitless adapter manufacturer		MERRILL		Model		SPK	
										☐ Casing Protection		☐ 12 in. above grade					
										☐ At-grade (Environmental Wells and Borings ONLY)							
										Grouting Information		Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
										Material		Amount		From		To	
										other				55 ft.		66 ft.	
										high solids bentonite				66 ft.		98 ft.	
										high solids bentonite		4 Sacks		ft.		55 ft.	
										Nearest Known Source of Contamination							
										80 feet		<u>West</u> Direction				<u>Other</u> Type	
										Well disinfected upon completion?		☐ Yes ☐ No					
										Pump ☐ Not Installed		Date Installed		11/07/2025			
										Manufacturer's name		FRANKLIN					
										Model Number		10FS05		HP 0.5		Volt 230	
										Length of drop pipe		40 ft		Capacity 10 g.p.		Typ Submersible	
										Abandoned							
										Does property have any not in use and not sealed well(s)?		☐ Yes ☐ No					
										Variance							
										Was a variance granted from the MDH for this well?		☐ Yes ☒ No					
										Miscellaneous							
										First Bedrock				Aquifer			
										Last Strat				Depth to Bedrock		ft	
										Located by							
										Locate Method							
										System		UTM - NAD83, Zone 15, Meters		X		Y	
										Unique Number Verification				Input Date			
										Angled Drill Hole							
										Well Contractor							
										Steffl Drilling and Pump, Inc.		1551		JONES, W.			
										Licensee Business		Lic. or Reg. No.		Name of Driller			