

890794

County Blue Earth
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date01/29/2026
Update Date01/29/2026
Received Date10/08/2025

Well Name HAGER, DOUG	Township 107	Range 27	Dir W	Section 25	Subsection DBC	Well Depth 150 ft.	Depth Completed 150 ft.	Date Well Completed 06/25/2025		
Elevation	Elev. Method					Drill Method Cable Tool	Drill Fluid Water			
Address C/W 56549 171 ST GOOD THUNDER MN 56037						Use domestic	Status Active			
						Well Hydrofractured? Yes ☐ No ☒		From To		
Stratigraphy Information						Casing Type Step down	Joint			
						Drive Shoe? Yes ☒ No ☐		Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter		Weight	Hole Diameter	
TOPSOIL		0	2	BLACK	SOFT	4 in. To 130 ft.		lbs./ft.	5 in. To 150 ft.	
CLA		2	25	YELLOW	SOFT	4 in. To ft.		130 lbs./ft.		
CLAY		25	50	GRAY	SOFT					
SAND		50	54	BROWN	SOFT					
CLAY/SAND		54	75	GRAY	SOFT					
SAND		75	82	GRAY	SOFT					
SAND/CLAY		82	110	GRAY	SOFT					
SAND		110	135	BROWN	SOFT					
SAND		135	150	GRAY	SOFT					
Remarks ELEV +-999						Open Hole				
						From		ft.	To	ft.
						Screen? ☒	Type	stainless	Make	JOHNSON
						Diameter	Slot/Gauze	Length	Set	
						4 in.	12	5 ft.	140 ft.	150 ft.
						Static Water Level				
						120 ft.	land surface		Measure	06/25/2025
						Pumping Level (below land surface)				
						130 ft.	4 hrs.	Pumping at	15	g.p.m.
						Wellhead Completion				
Pitless adapter manufacturer										
Model										
☐ Casing Protection ☐ 12 in. above grade										
☐ At-grade (Environmental Wells and Borings ONLY)										
Grouting Information										
Well Grouted? ☐ Yes ☐ No ☐ Not Specified										
Nearest Known Source of Contamination										
<u>100</u> feet <u>North</u> Direction <u>Sewer</u> Type										
Well disinfected upon completion? ☐ Yes ☐ No										
Pump ☐ Not Installed Date Installed <u>06/25/2025</u>										
Manufacturer's name <u>GRUNDFOS</u>										
Model Number <u>10SQ10-</u> HP <u>1</u> Volt <u>230</u>										
Length of drop pipe <u>130</u> ft Capacity <u>15</u> g.p. Typ <u>Submersible</u>										
Abandoned										
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No										
Variance										
Was a variance granted from the MDH for this well? ☐ Yes ☒ No										
Miscellaneous										
First Bedrock										
Last Strat										
Aquifer										
Depth to Bedrock										
ft										
Located by										
Locate Method										
System <u>UTM - NAD83, Zone 15, Meters</u> X Y										
Unique Number Verification										
Input Date										
Angled Drill Hole										
Well Contractor										
Denn Well Service, Inc.										
1699										
DENN, G+R										
Licensee Business										
Lic. or Reg. No.										
Name of Driller										