

890880

County Chisago
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/09/2026
Received Date 10/20/2025

Well Name NAWROCKI,	Township 37	Range 22	Dir W	Section 9	Subsection DAA	Well Depth 74 ft.	Depth Completed 74 ft.	Date Well Completed 09/25/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Well 52303 AZALEA AV STANCHFIELD MN						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact 7310 JACKSON ST NE FRIDLEY MN 55432						Casing Type Single casing Joint Glued		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
TOPSOIL		0	5	BLACK	SOFT	4 in. To 74 ft. lbs./ft. 8 in. To 50 ft.		
GRAVEL		5	20	GRAY	SOFT	6.7 in. To 74 ft.		
CLAY		20	61	GRAY	SOFT			
SAND		61	72	GRAY	SOFT			
CLAY		72	74	BROWN	SOFT			
						Open Hole From ft. To ft.		
						Screen? ☒ Type other Make BIGFOOT		
						Diameter Slot/Gauze Length Set		
						in. 10 ft. 62 ft. 72 ft.		
						Static Water Level		
						3 ft. land surface Measure 09/25/2025		
						Pumping Level (below land surface)		
						140 ft. 1 hrs. Pumping at 50 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer AQUASEAL Model 4X1		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						bentonite 4 Sacks ft. 50 ft.		
						Nearest Known Source of Contamination		
						35 feet West Direction Body of water Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 10/09/2025		
						Manufacturer's name GOULDS		
						Model Number 10CS05 HP 0.5 Volt 110		
						Length of drop pipe 20 ft Capacity g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☐ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Mork Well Co., Inc. 1877 DANIELSON, C		
						Licensee Business Lic. or Reg. No. Name of Driller		
Remarks								