

891140

County Wright
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 04/16/2026
Received Date 01/02/2026

Well Name KACZMAREK,					Township 119	Range 28	Dir Section W 11	Subsection CCA	Well Depth 93 ft.		Depth Completed 93 ft.		Date Well Completed 10/21/2025	
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Bentonite		
Address									Use domestic		Status Active			
C/W 2747 3 CR SW COKATO MN 55321									Well Hydrofractured? Yes ☐ No ☐		From To			
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY 0 26 BROWN HARD CLAY 26 75 GRAY MEDIUM SAND/ GRAVEL 75 93 VARIED SOFT									Casing Type Single casing		Joint Glued			
									Drive Shoe? Yes ☐ No ☐		Above/Below			
									Casing Diameter 4 in. To 89 ft.		Weight lbs./ft.			
									Hole Diameter 8.7 in. To 60 ft.					
									Hole Diameter 6.5 in. To 93 ft.					
Open Hole									From ft.		To ft.			
Screen? ☒									Type stainless		Make JOHNSON			
Diameter Slot/Gauze Length Set									3 in. 12 4 ft. 89 ft.		93 ft.			
Static Water Level									20 ft. land surface		Measure 10/21/2025			
Pumping Level (below land surface)									22 ft. 1.5 hrs. Pumping at		50 g.p.m.			
Wellhead Completion									Pitless adapter manufacturer BAKER		Model 6PS45BS4C			
☐ Casing Protection									☐ 12 in. above grade					
☐ At-grade (Environmental Wells and Borings ONLY)														
Grouting Information									Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material Amount From To									cuttings 60 ft. 85 ft.					
other 5									ft. 60 ft.					
Nearest Known Source of Contamination									95 feet East Direction		Other Type			
Well disinfected upon completion?									☒ Yes ☐ No					
Pump ☐ Not Installed									Date Installed 11/04/2025					
Manufacturer's name AERMOTOR														
Model Number S20-75 HP 0.75									Volt 230					
Length of drop pipe 63 ft Capacity 20 g.p.									Typ Submersible					
Abandoned									Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No			
Variance									Was a variance granted from the MDH for this well?		☐ Yes ☒ No			
Miscellaneous									First Bedrock		Aquifer			
Last Strat									Depth to Bedrock		ft			
Located by														
Locate Method														
System UTM - NAD83, Zone 15, Meters									X		Y			
Unique Number Verification											Input Date			
Angled Drill Hole														
Well Contractor									LTP Enterprises, Inc.		2157 SCHULTZ, C.			
Licensee Business									Lic. or Reg. No.		Name of Driller			