

891379

County Wright
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/04/2026
Update Date 05/04/2026
Received Date 03/02/2026

Well Name GREG ROEHL	Township 118	Range 25	Dir W	Section 23	Subsection AAA																														
Elevation Elev. Method																																			
Address Well 9069 17 CR SE DELANO MN 55328 Contact 9675 180TH AV SE BECKER MN 55308																																			
Stratigraphy Information <table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>CLAY</td><td>0</td><td>20</td><td>TAN</td><td>MEDIUM</td></tr><tr><td>CLAY</td><td>20</td><td>35</td><td>GRAY</td><td>MEDIUM</td></tr><tr><td>SAND + GRAVEL</td><td>35</td><td>44</td><td>BROWN</td><td>SOFT</td></tr><tr><td>CLAY</td><td>44</td><td>111</td><td>BROWN</td><td>MEDIUM</td></tr><tr><td>SAND</td><td>111</td><td>134</td><td>TAN</td><td>SOFT</td></tr></table>						Geological Material	From	To (ft.)	Color	Hardness	CLAY	0	20	TAN	MEDIUM	CLAY	20	35	GRAY	MEDIUM	SAND + GRAVEL	35	44	BROWN	SOFT	CLAY	44	111	BROWN	MEDIUM	SAND	111	134	TAN	SOFT
Geological Material	From	To (ft.)	Color	Hardness																															
CLAY	0	20	TAN	MEDIUM																															
CLAY	20	35	GRAY	MEDIUM																															
SAND + GRAVEL	35	44	BROWN	SOFT																															
CLAY	44	111	BROWN	MEDIUM																															
SAND	111	134	TAN	SOFT																															
Well Depth 134 ft.																																			
Depth Completed 134 ft.																																			
Date Well Completed 12/05/2025																																			
Drill Method Non-specified Rotary																																			
Drill Fluid Other																																			
Use domestic																																			
Status Active																																			
Well Hydrofractured? Yes ☐ No ☒ From To																																			
Casing Type Single casing																																			
Joint Glued																																			
Drive Shoe? Yes ☐ No ☒ Above/Below																																			
Casing Diameter Weight Hole Diameter																																			
4 in. To 129 ft. 2.1 lbs./ft. 8 in. To 30 ft.																																			
6.5 in. To 134 ft.																																			
Open Hole From ft. To ft.																																			
Screen? ☒ Type stainless Make JOHNSON																																			
Diameter Slot/Gauze Length Set																																			
2 in. 15 4 ft. 129 ft. 134 ft.																																			
Static Water Level																																			
40 ft. land surface Measure 12/02/2025																																			
Pumping Level (below land surface)																																			
ft. 1 hrs. Pumping at 30 g.p.m.																																			
Wellhead Completion																																			
Pitless adapter manufacturer AQUA SEAL Model T4-1																																			
☐ Casing Protection ☒ 12 in. above grade																																			
☐ At-grade (Environmental Wells and Borings ONLY)																																			
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified																																			
Material Amount From To																																			
cuttings 50 ft. 129 ft.																																			
high solids bentonite 4 Sacks ft. 50 ft.																																			
Nearest Known Source of Contamination																																			
53 feet Northwes Direction Sewer Type																																			
Well disinfected upon completion? ☐ Yes ☐ No																																			
Pump ☐ Not Installed Date Installed 12/05/2025																																			
Manufacturer's name GOULDS																																			
Model Number 18CS10 HP 1 Volt 230																																			
Length of drop pipe 80 ft Capacity 18 g.p. Typ Submersible																																			
Abandoned																																			
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																																			
Variance																																			
Was a variance granted from the MDH for this well? ☐ Yes ☒ No																																			
Miscellaneous																																			
First Bedrock Aquifer																																			
Last Strat Depth to Bedrock ft																																			
Located by																																			
Locate Method																																			
System UTM - NAD83, Zone 15, Meters X Y																																			
Unique Number Verification Input Date																																			
Angled Drill Hole																																			
Well Contractor																																			
Able Well, Inc. 1377 THOMPSON, S																																			
Licensee Business Lic. or Reg. No. Name of Driller																																			