

891752

County Douglas
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/10/2026
Received Date 01/12/2025

Well Name DKD	Township 128	Range 37	Dir W	Section 15	Subsection DAB	Well Depth 240 ft.	Depth Completed 230 ft.	Date Well Completed 09/23/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid	Other
Address						Use domestic	Status Active	
Contact 40158 330TH AV MELROSE MN 56352						Well Hydrofractured? Yes ☐ No ☒ From To		
Well 4698 GENEVA GOLF CLUB DR NE ALEXANDRIA MN						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
TOPSOIL		0	2	BLACK	MEDIUM	4 in. To 222 ft. lbs./ft. 7.8 in. To 240 ft.		
CLAY		2	30	BROWN	MEDIUM			
CLAY		30	190	GRAY	HARD			
SAND		190	230	GRAY	SOFT			
CLAY		230	240	GRAY	HARD			
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						4 in. 20 8 ft. 222 ft. 230 ft.		
						Static Water Level		
						46 ft. land surface Measure 09/23/2025		
						Pumping Level (below land surface)		
						220 ft. 1.5 hrs. Pumping at 100 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer GRADEA MAASS Model 4J1.25		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						bentonite 7 Sacks ft. 70 ft.		
						Nearest Known Source of Contamination		
						feet Direction Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 12/18/2025		
						Manufacturer's name GRUNDFOS		
						Model Number 22SQE10- HP 1 Volt 230		
						Length of drop pipe 80 ft Capacity 22 g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Steven M Traut Wells, Inc. 1889 RICK, D		
						Licensee Business Lic. or Reg. No. Name of Driller		