

891966

County St. Louis
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/30/2026
Update Date 04/30/2026
Received Date 01/26/2026

Well Name THORESON,					Township 52	Range 13	Dir W	Section 26	Subsection BCA	Well Depth 306 ft.		Depth Completed 306 ft.		Date Well Completed 11/18/2025					
Elevation					Elev. Method					Drill Method Driven		Drill Fluid Water							
Address										Use domestic		Status Active							
Well 6230 LAKEWOOD RD DULUTH MN 55804										Well Hydrofractured?		Yes ☒ No ☐		From		To			
Contact 1404 STANFORD AV DULUTH MN 55811										Casing Type Single casing		Joint							
Stratigraphy Information										Drive Shoe?		Yes ☒ No ☐		Above/Below					
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter		Weight		Hole Diameter									
ROCKY CLAY		0	60	BROWN	MEDIUM	6 in. To		153 ft. 19.45 lbs./ft.		6 in. To		306 ft.							
GRAVEL DRY		60	153	BROWN	HARD														
LEDGE		153	306	GREEN	M.HARD														
										Open Hole		From		ft.		To		ft.	
										Screen?		☐		Type		Make			
										Static Water Level									
										Pumping Level (below land surface)		ft.		hrs.		Pumping at		0.5 g.p.m.	
										Wellhead Completion		Pitless adapter manufacturer		Model					
										☐ Casing Protection		☒ 12 in. above grade							
										☐ At-grade (Environmental Wells and Borings ONLY)									
										Grouting Information		Well Grouted?		☒ Yes ☐ No ☐ Not Specified					
										Material		Amount		From		To			
										driven casing seal		7 Sacks		8		ft. 152		ft.	
										Nearest Known Source of Contamination		100 feet		South Direction		Septic tank/drain field		Type	
										Well disinfected upon completion?		☒ Yes ☐ No							
										Pump		☒ Not Installed		Date Installed					
										Manufacturer's name									
										Model Number		HP		Volt					
										Length of drop pipe		ft		Capacity		g.p.		Typ	
										Abandoned		Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No					
										Variance		Was a variance granted from the MDH for this well?		☐ Yes ☒ No					
										Miscellaneous		First Bedrock		Aquifer					
										Last Strat		Depth to Bedrock				ft			
										Located by									
										Locate Method									
										System		UTM - NAD83, Zone 15, Meters		X		Y			
										Unique Number Verification						Input Date			
										Angled Drill Hole									
										Well Contractor		Rasmussen Well Drilling, Inc.		1466		RASMUSSEN, R			
										Licensee Business		Lic. or Reg. No.				Name of Driller			