

892726

County Douglas
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 02/10/2026
Received Date 12/29/2025

Well Name KULZER, JAKE	Township 128	Range 38	Dir W	Section 16	Subsection ADA	Well Depth 102 ft.	Depth Completed 98 ft.	Date Well Completed 12/05/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Qwik gel	
Address						Use domestic	Status Active	
Contact 4047 34 CR NW ALEXANDRIA MN 56308						Well Hydrofractured? Yes ☐ No ☒ From To		
Well 716 TOWNHALL RD NW ALEXANDRIA MN 56308						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight		
CLAY		0	26	BROWN		4 in. To ft. 94 lbs./ft.		
SAND		26	39	BROWN				
SANDY CLAY		39	82	BROWN				
SAND		82	102	BROWN				
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						4 in. 10 4 ft. 94 ft. 98 ft.		
						Static Water Level		
						74 ft. land surface Measure 12/05/2025		
						Pumping Level (below land surface)		
						ft. 95 hrs. Pumping at 1 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer 20 Model		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						cuttings 60 ft. 85 ft.		
						other 85 ft. 98 ft.		
						bentonite ft. 60 ft.		
						Nearest Known Source of Contamination		
						feet Direction Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☒ Not Installed Date Installed		
						Manufacturer's name		
						Model Number HP Volt		
						Length of drop pipe ft Capacity g.p. Typ		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Darin Weisel Well Service 1359 WEISEL, O		
						Licensee Business Lic. or Reg. No. Name of Driller		