

892934

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/26/2026
Received Date 12/17/2025

Well Name TJB HOMES					Township 32	Range 23	Dir W	Section 4	Subsection CDC	Well Depth 200 ft.		Depth Completed 200 ft.		Date Well Completed 10/29/2025					
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Bentonite							
Address										Use domestic		Status Active							
Well 4973 149TH AV NE HAM LAKE MN 55304										Well Hydrofractured?		Yes ☐		No ☒		From		To	
Contact 9100 BALTIMORE ST BLAINE MN 55449										Casing Type Single casing		Joint Welded							
Stratigraphy Information										Drive Shoe?		Yes ☐		No ☒		Above/Below			
Geological Material										Casing Diameter		Weight							
SANDY CLAY										4 in.		To 183 ft.		1.9		lbs./ft.			
CLAY, GRAVEL										65		76		GRY/BLK		SFT-MED			
CLAY										76		82		GRAY		SFT-MED			
SAND										82		89		RED/BRN		SOFT			
CLAY										89		155		RED		SFT-MED			
SAND										155		161		BROWN		SOFT			
CLAY, GRAVEL										161		180		BROWN		SOFT			
SAND, GRAVEL										180		200		BROWN		SOFT			
										Open Hole		From		ft.		To		ft.	
Screen? ☒										Type		other		Make		JET STREAM			
Diameter										Slot/Gauze		Length		Set					
4 in.										10		15 ft.		183 ft.		198 ft.			
										Static Water Level		30 ft.		land surface		Measure		10/29/2025	
										Pumping Level (below land surface)		183 ft.		2 hrs.		Pumping at		50 g.p.m.	
										Wellhead Completion		Pitless adapter manufacturer		MERRILL		Model		MCK7	
										☒ Casing Protection		☒ 12 in. above grade							
										☐ At-grade (Environmental Wells and Borings ONLY)									
										Grouting Information		Well Grouted?		☒ Yes		☐ No		☐ Not Specified	
										Material		Amount		From		To			
										cuttings				50		ft. 183		ft.	
										other		4 Sacks				ft. 50		ft.	
										Nearest Known Source of Contamination		50 feet		North Direction		Septic tank/drain field		Type	
										Well disinfected upon completion?		☒ Yes		☐ No					
										Pump ☐ Not Installed		Date Installed		10/30/2025					
										Manufacturer's name		GRUNDFOS							
										Model Number		22SQE15-		HP 1.5		Volt		230	
										Length of drop pipe		60 ft		Capacity		22 g.p.		Typ Submersible	
										Abandoned		Does property have any not in use and not sealed well(s)?		☐ Yes		☒ No			
										Variance		Was a variance granted from the MDH for this well?		☐ Yes		☒ No			
										Miscellaneous		First Bedrock		Aquifer					
										Last Strat		Depth to Bedrock				ft			
										Located by									
										Locate Method									
										System		UTM - NAD83, Zone 15, Meters		X		Y			
										Unique Number Verification						Input Date			
										Angled Drill Hole									
										Well Contractor		McAlpines Well Drilling of		1477		MCALPINE, R			
										Licensee Business		Lic. or Reg. No.				Name of Driller			