

892937

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/28/2026
Received Date 12/17/2025

Well Name PREMIER	Township 33	Range 24	Dir W	Section 5	Subsection DCC	Well Depth 134 ft.	Depth Completed 134 ft.	Date Well Completed 11/13/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Well 3577 221ST AV NW OAK GROVE MN 55303						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact 17025 YALE ST NW ELK RIVER MN 55330						Casing Type Single casing Joint Welded		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☐ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight		
SAND		0	20	BROWN	SOFT	4 in. To 124 ft. 1.9 lbs./ft.		
CLAY, GRAVEL SAND		20	52	BRN/BLK	SOFT			
CLAY		52	65	GRAY	M.HARD			
CLAY		65	80	RED/BRN	M.HARD			
CLAY		80	91	BROWN	M.HARD			
CLAY, GRAVEL		91	97	BRN/BLK	MEDIUM			
CLAY, SAND		97	124	BROWN	SFT-MED			
SAND		124	134	BROWN	SOFT			
						Open Hole From ft. To ft.		
						Screen? ☒ Type Make JET STREAM		
						Diameter Slot/Gauze Length Set		
						4 in. 10 10 ft. 124 ft. 134 ft.		
						Static Water Level		
						30 ft. land surface Measure 11/13/2025		
						Pumping Level (below land surface)		
						124 ft. 2 hrs. Pumping at 50 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer MERRILL Model MCK7		
						☒ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						cuttings 50 ft. 124 ft.		
						other 4 Sacks ft. 50 ft.		
						Nearest Known Source of Contamination		
						50 feet North Direction Septic tank/drain field Type		
						Well disinfected upon completion? ☐ Yes ☐ No		
						Pump ☐ Not Installed Date Installed 11/18/2025		
						Manufacturer's name GRUNDFOS		
						Model Number 22SQE10- HP 1 Volt 230		
						Length of drop pipe 60 ft Capacity 22 g.p. Typ Submersible		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						McAlpines Well Drilling of 1477 MCALPINE, R		
						Licensee Business Lic. or Reg. No. Name of Driller		
Remarks								