

892940

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/26/2026
Received Date 12/17/2025

Well Name PREMIER	Township 32	Range 22	Dir W	Section 22	Subsection BDD	Well Depth 120 ft.	Depth Completed 120 ft.	Date Well Completed 11/20/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Well 6798 153RD LA NW RAMSEY MN 55303						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact 17205 YALE ST NW ELK RIVER MN 55330						Casing Type Single casing Joint Welded		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight		
SAND		0	20	BROWN	SOFT	4 in. To 110 ft. 1.9 lbs./ft.		
SAND, GRAVEL		20	30	BRN/BLK	SOFT			
CLAY, SAND, GRAVEL		30	86	BRN/BLK	SFT-MED			
CLAY, GRAVEL, ROCK		86	92	BRN/BLK	M.HARD			
ROCK		92	93	WHITE	HARD			
SAND		93	120	BROWN	SOFT			
Open Hole						From	ft.	To ft.
Screen? ☒						Type other	Make JET STREAM	
Diameter						Slot/Gauze	Length	Set
4 in.						12	10 ft.	110 ft. 120 ft.
Static Water Level								
20 ft.						land surface	Measure	11/20/2025
Pumping Level (below land surface)								
110 ft.						2 hrs.	Pumping at	50 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						MERRILL	Model	MCK7
☒ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material						Amount	From	To
cuttings							50 ft.	110 ft.
other						4 Sacks	ft.	50 ft.
Nearest Known Source of Contamination								
50 feet						South Direction	Septic tank/drain field Type	
Well disinfected upon completion?						☒ Yes ☐ No		
Pump ☐ Not Installed						Date Installed	11/21/2025	
Manufacturer's name						FLINT AND WALLING		
Model Number						HP	Volt	
FW10S07						0.75	230	
Length of drop pipe						Capacity	g.p.	Typ Submersible
60 ft						10		
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No		
Variance								
Was a variance granted from the MDH for this well?						☐ Yes ☒ No		
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock	ft	
Located by								
Locate Method								
System						UTM - NAD83, Zone 15, Meters	X	Y
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
McAlpines Well Drilling of						1477	MCALPINE, T	
Licensee Business						Lic. or Reg. No.	Name of Driller	