

892941

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/26/2026
Received Date 12/17/2025

Well Name T.H	Township 32	Range 23	Dir W	Section 4	Subsection ABD
Elevation	Elev. Method				
Address					
Contact 617 MAIN ST E ANOKA MN 55303					
Well 17961 STAPLES ST NE HAM LAKE MN					
Stratigraphy Information					
Geological Material		From	To (ft.)	Color	Hardness
SAND, CLAY		0	20	BROWN	SOFT
SANDY CLAY		20	91	BROWN	SOFT
GRAVEL		91	95	GRAY	SOFT
CLAY, GRAVEL		95	107	RED/BRN	SFT-MED
SAND		107	134	TAN	SOFT
Well Depth 134 ft.					
Depth Completed 134 ft.					
Date Well Completed 12/05/2025					
Drill Method Non-specified Rotary					
Drill Fluid Bentonite					
Use domestic					
Status Active					
Well Hydrofractured? Yes ☐ No ☐					
From To					
Casing Type Single casing					
Joint Welded					
Drive Shoe? Yes ☐ No ☒					
Above/Below					
Casing Diameter Weight					
4 in. To 113 ft. 1.9 lbs./ft.					
Open Hole From ft. To ft.					
Screen? ☒ Type other Make JET STREAM					
Diameter Slot/Gauze Length Set					
4 in. 8 20 ft. 113 ft. 133 ft.					
Static Water Level					
30 ft. land surface Measure 12/05/2025					
Pumping Level (below land surface)					
113 ft. 2 hrs. Pumping at 40 g.p.m.					
Wellhead Completion					
Pitless adapter manufacturer MERRILL Model MCK7					
☒ Casing Protection ☒ 12 in. above grade					
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material Amount From To					
cuttings 50 ft. 113 ft.					
other 3 Sacks ft. 50 ft.					
Nearest Known Source of Contamination					
50 feet North Direction Septic tank/drain field Type					
Well disinfected upon completion? ☐ Yes ☐ No					
Pump ☐ Not Installed Date Installed 12/06/2025					
Manufacturer's name FLINT AND WALLING					
Model Number FW19S10 HP 1 Volt 230					
Length of drop pipe 80 ft Capacity 19 g.p. Typ Submersible					
Abandoned					
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First Bedrock Aquifer					
Last Strat Depth to Bedrock ft					
Located by					
Locate Method					
System UTM - NAD83, Zone 15, Meters X Y					
Unique Number Verification Input Date					
Angled Drill Hole					
Well Contractor					
McAlpines Well Drilling of 1477 MCALPINE, R					
Licensee Business Lic. or Reg. No. Name of Driller					
Remarks					