

892942

County Anoka
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/26/2026
Received Date 12/17/2025

Well Name PREMIER	Township 32	Range 23	Dir W	Section 7	Subsection ACA	Well Depth 135 ft.	Depth Completed 135 ft.	Date Well Completed 12/09/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
Well 16936 VANBUREN ST NE HAM LAKE MN						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact 17025 YALE ST NW ELK RIVER MN 55330						Casing Type Single casing Joint Welded		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight		
SANDY CLAY		0	10	BROWN	SOFT	4 in. To 125 ft. 1.9 lbs./ft.		
CLAY, SAND		10	60	BROWN	SFT-MED			
CLAY		60	72	RED	MEDIUM			
CLAY, SAND		72	87	BROWN	MEDIUM			
CLAY, GRAVEL		87	107	BRN/BLK	MED-HRD			
SAND		107	135	BROWN	SOFT			
Open Hole						From	ft.	To ft.
Screen? ☒						Type other	Make JET STREAM	
Diameter						Slot/Gauze	Length	Set
4 in.						12	10 ft.	125 ft. 135 ft.
Static Water Level								
30 ft.						land surface	Measure	12/09/2025
Pumping Level (below land surface)								
125 ft.						2 hrs.	Pumping at	50 g.p.m.
Wellhead Completion								
Pitless adapter manufacturer						MERRILL	Model	MCK7
☒ Casing Protection						☒ 12 in. above grade		
☐ At-grade (Environmental Wells and Borings ONLY)								
Grouting Information						Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
Material						Amount	From	To
cuttings							50 ft.	125 ft.
other						4 Sacks	ft.	50 ft.
Nearest Known Source of Contamination								
50 feet						Northwes Direction	Septic tank/drain field	Type
Well disinfected upon completion?						☐ Yes ☐ No		
Pump ☐ Not Installed						Date Installed	12/10/2025	
Manufacturer's name						FLINT AND WALLING		
Model Number						HP	Volt	
FW10S07						0.75	230	
Length of drop pipe						ft	Capacity	g.p. Typ Submersible
80						10		
Abandoned								
Does property have any not in use and not sealed well(s)?						☐ Yes ☒ No		
Variance								
Was a variance granted from the MDH for this well?						☐ Yes ☒ No		
Miscellaneous								
First Bedrock						Aquifer		
Last Strat						Depth to Bedrock	ft	
Located by								
Locate Method								
System						UTM - NAD83, Zone 15, Meters	X	Y
Unique Number Verification						Input Date		
Angled Drill Hole								
Well Contractor								
McAlpines Well Drilling of						1477	MCALPINE, T	
Licensee Business						Lic. or Reg. No.	Name of Driller	