

893108

County Scott
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/05/2026
Update Date 05/05/2026
Received Date 01/13/2026

Well Name KUSSKE, STEVE					Township 114		Range 21		Dir Section W 29		Subsection BBD		Well Depth 180 ft.		Depth Completed 180 ft.		Date Well Completed 12/10/2025								
Elevation					Elev. Method					Drill Method Non-specified Rotary				Drill Fluid Water											
Address												Use domestic		Status Active											
C/W 7717 LONGVIEW LA PRIOR LAKE MN												Well Hydrofractured? Yes ☐ No ☒				From		To							
Stratigraphy Information												Casing Type Single casing		Joint Welded											
Drive Shoe? Yes ☒ No ☐												Above/Below													
Geological Material												From		To (ft.)		Color		Hardness							
CLAY + SAND												0		17		BROWN		SOFT							
CLAY + SAND												17		150		GRAY		SOFT							
CLAY												150		162		GRAY		V.SOFT							
SAND, GRAVEL,												162		174		BROWN		SFT-MED							
LIME ROCK												174		180		GRAY		HARD							
Open Hole												From		175		ft.		To		180		ft.			
Screen? ☐												Type				Make									
Static Water Level												41		ft.		land surface				Measure		12/09/2025			
Pumping Level (below land surface)												ft.		hrs.		Pumping at				g.p.m.					
Wellhead Completion												Pitless adapter manufacturer				MONITOR		Model							
☐ Casing Protection												☐ 12 in. above grade													
☐ At-grade (Environmental Wells and Borings ONLY)																									
Grouting Information												Well Grouted? ☒ Yes ☐ No ☐ Not Specified													
Material												Amount				From		To							
bentonite												5 Sacks				ft.		175		ft.					
Nearest Known Source of Contamination												22 feet				Northwes Direction				Sewer Type					
Well disinfected upon completion?												☒ Yes ☐ No													
Pump ☐ Not Installed												Date Installed				12/10/2025									
Manufacturer's name												F+W													
Model Number												4F19S15		HP		1.5		Volt		240					
Length of drop pipe												63		ft		Capacity		19		g.p.		Typ		Submersible	
Abandoned												Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No													
Variance												Was a variance granted from the MDH for this well? ☐ Yes ☒ No													
Miscellaneous												First Bedrock										Aquifer			
Last Strat																						Depth to Bedrock		ft	
Located by																									
Locate Method																									
System												UTM - NAD83, Zone 15, Meters				X		Y							
Unique Number Verification																						Input Date			
Angled Drill Hole																									
Well Contractor												Hartmann Well Co., LLP										1622		HARTMANN, W	
Licensee Business																						Lic. or Reg. No.		Name of Driller	