

893139

County Scott
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/05/2026
Update Date 05/05/2026
Received Date 03/02/2026

Well Name FISTIOVICH,	Township 113	Range 22	Dir Section W 35	Subsection DBA	Well Depth 180 ft.	Depth Completed 180 ft.	Date Well Completed 02/04/2026			
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Water				
Address C/W 27522 ZACHARY AV ELKO MN 55020					Use domestic	Status Active				
					Well Hydrofractured? Yes ☐ No ☒ From			To		
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY 0 15 BROWN SOFT CLAY 15 117 GRAY SOFT CLAY + SAND 117 166 GRAY SOFT SAND 166 180 BROWN SOFT					Casing Type Single casing	Joint Glued				
					Drive Shoe? Yes ☐ No ☒ Above/Below					
					Casing Diameter 4 in. To		Weight 170 ft. lbs./ft.		Hole Diameter 6.5 in. To 180 ft.	
					Open Hole From ft. To ft.					
					Screen? ☒		Type plastic		Make MONOFLEX	
					Diameter 4 in.		Slot/Gauze 10		Length 170 ft. 180 ft.	
					Static Water Level 49 ft. land surface Measure 10/23/2025					
					Pumping Level (below land surface) ft. hrs. Pumping at g.p.m.					
					Wellhead Completion Pitless adapter manufacturer MONITOR Model ☐ Casing Protection ☐ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)					
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To bentonite 2 Sacks ft. 50 ft.					
Nearest Known Source of Contamination 53 feet <u>Northeas</u> Direction <u>Septic tank/drain field</u> Type Well disinfected upon completion? ☒ Yes ☐ No										
Pump ☐ Not Installed Date Installed <u>02/04/2026</u> Manufacturer's name F+W Model Number <u>4F19S15</u> HP <u>1.5</u> Volt <u>230</u> Length of drop pipe <u>80</u> ft Capacity <u>19</u> g.p. Typ <u>Submersible</u>										
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No										
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No										
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date										
Angled Drill Hole										
Well Contractor Hartmann Well Co., LLP 1622 HARTMANN, O Licensee Business Lic. or Reg. No. Name of Driller										