

893404

County Pine
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/10/2026
Update Date 04/10/2026
Received Date 11/03/2025

Well Name THOMPSON,	Township 38	Range 22	Dir Section W 11	Subsection BDD	Well Depth 132 ft.	Depth Completed 132 ft.	Date Well Completed 10/20/2025
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Qwik gel	
Address C/W 9153 BOARS EAR RD PINE CITY MN 55063					Use domestic	Status Active	
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY & ROCKS 0 42 BROWN MEDIUM CLAY & GRAVEL 42 85 BROWN MEDIUM CLAY & ROCKS 85 124 GRAY HARD GRAVEL 124 132 GRAY MEDIUM					Well Hydrofractured? Yes ☐ No ☐ From To		
					Casing Type Single casing Joint		
					Drive Shoe? Yes ☐ No ☒ Above/Below		
					Casing Diameter Weight Hole Diameter 4 in. To 127 ft. lbs./ft. 7.8 in. To 132 ft.		
					Open Hole From ft. To ft.		
					Screen? ☒ Type stainless Make JOHNSON Diameter Slot/Gauze Length Set 3 in. 15 5 ft. 127 ft. 132 ft.		
					Static Water Level 30 ft. land surface Measure 10/17/2025		
					Pumping Level (below land surface) 120 ft. 2 hrs. Pumping at 35 g.p.m.		
					Wellhead Completion Pitless adapter manufacturer BAKER Model SNAPPY ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)		
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To high solids bentonite 6.5 Sacks ft. 50 ft.		
Nearest Known Source of Contamination 50 feet North Direction Sewer Type Well disinfected upon completion? ☐ Yes ☐ No							
Pump ☐ Not Installed Date Installed 10/18/2025 Manufacturer's name GRUNDFOS Model Number SQ40-65- HP 0.5 Volt 250 Length of drop pipe 60 ft Capacity 10 g.p. Typ Submersible							
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No							
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No							
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date							
Angled Drill Hole							
Well Contractor Mora Well Co. 1512 JASON Licensee Business Lic. or Reg. No. Name of Driller							