

893580

County St. Louis
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/30/2026
Update Date 04/30/2026
Received Date 01/22/2026

Well Name NELSON,					Township 61	Range 13	Dir W	Section 25	Subsection DCD	Well Depth 45 ft.			Depth Completed 45 ft.			Date Well Completed 12/14/2025					
Elevation					Elev. Method					Drill Method Multiple methods used			Drill Fluid Water								
Address										Use domestic			Status Active								
Contact 4721 13TH AV S MINNEAPOLIS MN 55407										Well Hydrofractured? Yes ☐ No ☒			From			To					
Well 8512 KRAMER BAY RD BABBITT MN 55706										Casing Type Single casing			Joint Welded								
Stratigraphy Information										Drive Shoe? Yes ☒ No ☐			Above/Below								
Geological Material					From		To (ft.)		Color		Hardness		Casing Diameter			Weight			Hole Diameter		
SAND + SILTY CLAY					0		13		BROWN		SOFT		6 in. To 21 ft. 20 lbs./ft.			6 in. To 45 ft.					
CLAY					13		17		BROWN		MEDIUM										
HARD PAN					17		21		GRAY		HARD										
LEDGE ROCK					21		45		GREEN		MEDIUM										
										Open Hole			From 21 ft.		To 45 ft.						
										Screen? ☐			Type		Make						
Static Water Level										8 ft.		land surface		Measure		12/14/2025					
Pumping Level (below land surface)										ft.		hrs.		Pumping at		g.p.m.					
Wellhead Completion										Pitless adapter manufacturer			Model								
☐ Casing Protection										☒ 12 in. above grade											
☐ At-grade (Environmental Wells and Borings ONLY)																					
Grouting Information										Well Grouted?		☒ Yes ☐ No ☐ Not Specified									
Material					Amount					From		To									
driven casing seal					1 Sacks					ft. 45		ft.									
Nearest Known Source of Contamination										50 feet		North Direction		Body of water		Type					
Well disinfected upon completion?										☒ Yes ☐ No											
Pump ☐ Not Installed										Date Installed		12/10/2025									
Manufacturer's name										SCHAEFER											
Model Number					10SRD05S4		HP		0.5		Volt		230								
Length of drop pipe					18 ft		Capacity		g.p.		Typ		Submersible								
Abandoned										Does property have any not in use and not sealed well(s)?			☐ Yes ☒ No								
Variance										Was a variance granted from the MDH for this well?			☐ Yes ☒ No								
Miscellaneous										First Bedrock			Aquifer								
Last Strat										Depth to Bedrock			ft								
Located by										Locate Method											
System					UTM - NAD83, Zone 15, Meters					X		Y									
Unique Number Verification										Input Date											
Angled Drill Hole																					
Well Contractor										Froe Bros Drilling			4125		FROEHLINGS DOR						
Licensee Business					Lic. or Reg. No.					Name of Driller											
Remarks																					