

893616

County Hubbard
Quad Mantrap
Quad ID 278C

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 01/06/2026
Update Date 02/16/2026
Received Date 07/30/2025

Well Name DUDLEY, CLINT	Township 141	Range 33	Dir W	Section 30	Subsection ABCABA
Elevation	Elev. Method				
Address					
Contact	22248 236TH ST NEVIS MN 56467				
Well	22128 236TH ST NEVIS MN 56457				
Stratigraphy Information					
Geological Material	From	To (ft.)	Color	Hardness	
TOP SOIL	0	1	BLACK	SOFT	
SAND	1	60	BROWN	MEDIUM	
SAND	60	78	GRAY	MEDIUM	
Well Depth 78 ft.					
Depth Completed 78 ft.					
Date Well Completed 07/30/2025					
Drill Method Non-specified Rotary					
Drill Fluid Bentonite					
Use domestic					
Status Active					
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing Type Single casing					
Joint					
Drive Shoe? Yes ☐ No ☒ Above/Below					
Casing Diameter Weight Hole Diameter					
4 in. To 74 ft. 2.2 lbs./ft. 6.7 in. To 78 ft.					
Open Hole From ft. To ft.					
Screen? ☒ Type stainless Make JOHNSON					
Diameter Slot/Gauze Length Set					
4 in. 12 4 ft. 74 ft. 78 ft.					
Static Water Level					
64 ft. land surface Measure 07/31/2025					
Pumping Level (below land surface)					
74 ft. 2 hrs. Pumping at 18 g.p.m.					
Wellhead Completion					
Pitless adapter manufacturer SNAPPY MONIT Model 4X1					
☐ Casing Protection ☒ 12 in. above grade					
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material Amount From To					
other 4.5 Sacks ft. 50 ft.					
Nearest Known Source of Contamination					
64 feet South Direction Septic tank/drain field Type					
Well disinfected upon completion? ☒ Yes ☐ No					
Pump ☐ Not Installed Date Installed 08/01/2025					
Manufacturer's name FRANKLIN SCHAEFER					
Model Number 320055 HP 0.5 Volt 230					
Length of drop pipe 60 ft Capacity 10 g.p. Typ Submersible					
Abandoned					
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First Bedrock Aquifer					
Last Strat Depth to Bedrock ft					
Located by Minnesota Department of Health					
Locate Method GPS SA Off (averaged) (15 meters)					
System UTM - NAD83, Zone 15, Meters X 355157 Y 5207529					
Unique Number Verification Info/GPS from data Input Date 01/06/2026					
Angled Drill Hole					
Well Contractor					
North Star Drilling 3246 SKOOG, W					
Licensee Business Lic. or Reg. No. Name of Driller					