

894070

County Otter Tail
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 04/29/2026
Received Date 02/04/2026

Well Name WEST, HEATH					Township 132	Range 39	Dir W	Section 5	Subsection BCD	Well Depth 65 ft.		Depth Completed 60 ft.		Date Well Completed 10/12/2025			
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Qwik gel					
Address										Use domestic		Status Active					
C/W 41565 THUNDER RD CLITHERALL MN										Well Hydrofractured?		Yes ☐ No ☒		From		To	
Stratigraphy Information										Casing Type Single casing		Joint					
										Drive Shoe?		Yes ☐ No ☐		Above/Below			
Geological Material										From		To (ft.)		Color		Hardness	
GRAVEL										0		20		BROWN		MEDIUM	
SAND										20		60		BROWN		MEDIUM	
CLAY										60		65					
										Casing Diameter		Weight		Hole Diameter			
										4 in. To		56 ft. lbs./ft.		6.5 in. To 65 ft.			
										Open Hole		From ft.		To ft.			
										Screen? ☒		Type stainless		Make JOHNSON			
										Diameter		Slot/Gauze Length		Set			
										4 in.		12		4 ft.		56 ft. 60 ft.	
										Static Water Level							
										30 ft.		land surface		Measure		10/12/2025	
										Pumping Level (below land surface)							
										50 ft.		1 hrs.		Pumping at		20 g.p.m.	
										Wellhead Completion							
										Pitless adapter manufacturer		MONITOR		Model		4BO	
										☐ Casing Protection		☒ 12 in. above grade					
										☐ At-grade (Environmental Wells and Borings ONLY)							
										Grouting Information		Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
										Material		Amount		From		To	
										cuttings				50 ft.		56 ft.	
										bentonite		2 Sacks		ft. 50		ft.	
										Nearest Known Source of Contamination							
										75 feet		Northwes Direction		Sewer Type			
										Well disinfected upon completion?		☒ Yes ☐ No					
										Pump ☐ Not Installed		Date Installed					
										Manufacturer's name							
										Model Number		HP		Volt			
										Length of drop pipe		ft		Capacity		g.p. Typ	
										Abandoned							
										Does property have any not in use and not sealed well(s)?		☐ Yes ☒ No					
										Variance							
										Was a variance granted from the MDH for this well?		☐ Yes ☒ No					
										Miscellaneous							
										First Bedrock		Aquifer					
										Last Strat		Depth to Bedrock		ft			
										Located by							
										Locate Method							
										System		UTM - NAD83, Zone 15, Meters		X		Y	
										Unique Number Verification				Input Date			
										Angled Drill Hole							
										Well Contractor							
										Reinart Bros. Well		78642		BURMEISTER, B			
										Licensee Business		Lic. or Reg. No.		Name of Driller			