

894115

County Wright
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/04/2026
Update Date 05/04/2026
Received Date 01/28/2026

Well Name UECKER, BRUCE 118	Township 26	Range W 12	Dir Section DDD	Subsection	Well Depth 140 ft.	Depth Completed 140 ft.	Date Well Completed 11/21/2025		
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Bentonite			
Address C/W 7750 MERIDIAN AV S MONTROSE MN 55363					Use domestic	Status Active			
Stratigraphy Information Geological Material From To (ft.) Color Hardness CLAY 0 5 BROWN SOFT GRAVEL 5 14 VARIED SOFT CLAY 14 22 GRAY MEDIUM FINE SAND 22 37 BROWN SOFT CLAY/ SAND 37 123 GRAY SOFT SAND/ GRAVEL 123 140 GRAY SOFT					Well Hydrofractured? Yes ☐ No ☒ From To				
					Casing Type Single casing	Joint			
					Drive Shoe? Yes ☐ No ☒	Above/Below			
					Casing Diameter 4 in. To 130 ft.	Weight lbs./ft.	Hole Diameter 8 in. To 50 ft. 6.5 in. To 140 ft.		
					Open Hole Screen? ☒	From ft.	To ft.	Type stainless	Make JOHNSON
					Diameter 2 in.	Slot/Gauze 12	Length 8 ft.	Set 130 ft.	140 ft.
					Static Water Level 20 ft. land surface Measure 11/21/2025				
					Pumping Level (below land surface) 125 ft. 2 hrs. Pumping at 75 g.p.m.				
					Wellhead Completion Pitless adapter manufacturer WHITEWATER Model ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)				
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified Material Amount From To cuttings 50 ft. 130 ft. bentonite 4 Sacks ft. 50 ft.				
Nearest Known Source of Contamination 90 feet North Direction Septic tank/drain field Type Well disinfected upon completion? ☐ Yes ☐ No									
Pump ☒ Not Installed Date Installed Manufacturer's name Model Number HP Volt Length of drop pipe ft Capacity g.p. Typ									
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date									
Angled Drill Hole									
Well Contractor Don Stodola Well Drilling 1691 STODOLA, R Licensee Business Lic. or Reg. No. Name of Driller									