

894240

County Swift
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/12/2026
Received Date 11/25/2025

Well Name GJERDE, MARTY 122					Township 38	Range W 14	Dir Section CCA	Well Depth 210 ft.					Depth Completed 210 ft.					Date Well Completed 11/04/2025																
Elevation					Elev. Method					Drill Method Non-specified Rotary					Drill Fluid Bentonite																			
Address										Use irrigation					Status Active																			
Well 55TH ST NE BENSON MN										Well Hydrofractured? Yes ☐ No ☐					From To																			
Contact 25355 SILVER BEACH RD GLENWOOD MN 56334										Casing Type Single casing					Joint																			
Stratigraphy Information										Drive Shoe? Yes ☐ No ☐					Above/Below																			
Geological Material					From	To (ft.)	Color	Hardness	Casing Diameter					Weight					Hole Diameter															
TOPSOIL					0	1	BLACK	SOFT	12 in. To					170 ft. 50 lbs./ft.					17. in. To 210 ft.															
SAND GRAVEL ROCKS					1	22	BROWN	MEDIUM																										
CLAY					22	33	BROWN	MEDIUM																										
CLAY					33	165	GRAY	MEDIUM																										
SHARP SAND					165	210	GRAY	MEDIUM																										
										Open Hole					From					ft.					To					ft.				
										Screen? ☒					Type stainless					Make JOHNSON														
										Diameter					Slot/Gauze					Length					Set									
										12 in.					70					40 ft.					170 ft. 210 ft.									
										Static Water Level																								
										38 ft.					land surface					Measure					11/04/2025									
										Pumping Level (below land surface)																								
										170 ft.					5 hrs.					Pumping at					1500 g.p.m.									
										Wellhead Completion																								
										Pitless adapter manufacturer										Model														
										☐ Casing Protection					☒ 12 in. above grade																			
										☐ At-grade (Environmental Wells and Borings ONLY)																								
										Grouting Information										Well Grouted? ☒ Yes ☐ No ☐ Not Specified														
										Material					Amount					From					To									
										other										ft. 50					ft.									
										Nearest Known Source of Contamination																								
										feet					Direction					Type														
										Well disinfected upon completion?										☒ Yes ☐ No														
										Pump ☐ Not Installed										Date Installed														
										Manufacturer's name																								
										Model Number					HP					Volt														
										Length of drop pipe					ft					Capacity					g.p. Typ									
										Abandoned																								
										Does property have any not in use and not sealed well(s)?										☐ Yes ☒ No														
										Variance																								
										Was a variance granted from the MDH for this well?										☐ Yes ☒ No														
										Miscellaneous																								
										First Bedrock					Aquifer																			
										Last Strat					Depth to Bedrock					ft														
										Located by																								
										Locate Method																								
										System					UTM - NAD83, Zone 15, Meters					X					Y									
										Unique Number Verification										Input Date														
										Angled Drill Hole																								
										Well Contractor																								
										Klimek Bros. Well Drilling,					1864					KLIMEK, D.														
										Licensee Business					Lic. or Reg. No.					Name of Driller														