

894468

County Itasca
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/20/2026
Received Date 01/12/2026

Well Name SNYDER, COLE					Township 55	Range 27	Dir W	Section 12	Subsection DAB
Elevation					Elev. Method				
Address									
Contact					44916 162 CR DEER RIVER MN 56636				
Well					40362 249 CR COHASSET MN 55721				
Stratigraphy Information									
Geological Material		From	To (ft.)	Color	Hardness				
TOP SOIL		0	1	BLACK	SOFT				
LOAMY		1	9	BROWN	MEDIUM				
CLAY GRAVEL		9	24	BROWN	HARD				
FINE SANDS		24	30	BROWN	SOFT				
ROCKY CLAY GRAVEL		30	75	GRAY	HARD				
FINE EVEN SANDS		75	81	LT. BRN	SOFT				
Well Depth 81 ft.									
Depth Completed 81 ft.									
Date Well Completed 12/01/2025									
Drill Method Non-specified Rotary					Drill Fluid Bentonite				
Use domestic					Status Active				
Well Hydrofractured? Yes ☐ No ☒ From To									
Casing Type Single casing Joint									
Drive Shoe? Yes ☐ No ☒ Above/Below									
Casing Diameter 4 in. To 76 ft.					Weight lbs./ft.			Hole Diameter 7.8 in. To 81 ft.	
Open Hole From ft. To ft.									
Screen? ☒ Type stainless Make JOHNSON									
Diameter 3 in.		Slot/Gauze 10		Length 5 ft.		Set 76 ft.		81 ft.	
Static Water Level 24 ft. land surface Measure 12/01/2025									
Pumping Level (below land surface) 81 ft. 2 hrs. Pumping at 20 g.p.m.									
Wellhead Completion Pitless adapter manufacturer MONITOR Model SPK-4 ☐ Casing Protection ☒ 12 in. above grade ☐ At-grade (Environmental Wells and Borings ONLY)									
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified									
Material other bentonite		Amount Sacks		From 50 ft.		To 81 ft.		ft.	
Nearest Known Source of Contamination 69 feet South Direction Septic tank/drain field Type Well disinfected upon completion? ☒ Yes ☐ No									
Pump ☐ Not Installed Date Installed 12/01/2025 Manufacturer's name GOULDS Model Number 10CS05 HP 0.5 Volt 230 Length of drop pipe 65 ft Capacity 12 g.p. Typ Submersible									
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date									
Angled Drill Hole									
Well Contractor Runyan Well Drilling 1903 VILLENEUVE, D Licensee Business Lic. or Reg. No. Name of Driller									