

894852

County McLeod
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 04/06/2026
Update Date 04/06/2026
Received Date 01/05/2026

Well Name SANGREN, DAN	Township 117	Range 28	Dir W	Section 26	Subsection CDD
Elevation	Elev. Method				
Address					
Contact 205 CIRCLE VIEW DR DASSEL MN 55325					
Well 20115 GRAIN AV SILVER LAKE MN					
Stratigraphy Information					
Geological Material		From	To (ft.)	Color	Hardness
CLAY		0	20	YELLOW	
CLAY		20	108	BLUE	
SANDY CLAY		108	116	BLUE	
SAND		116	128		
CLAY + SAND		128	174	BLUE	
SAND		174	187		
Well Depth 187 ft. Depth Completed 187 ft. Date Well Completed 12/17/2025					
Drill Method Non-specified Rotary		Drill Fluid Qwik gel			
Use domestic				Status Active	
Well Hydrofractured? Yes ☐ No ☒ From To					
Casing Type Single casing Joint Glued					
Drive Shoe? Yes ☐ No ☒ Above/Below					
Casing Diameter		Weight		Hole Diameter	
4 in. To		181 ft. lbs./ft.		6.7 in. To 187 ft.	
Open Hole From ft. To ft.					
Screen? ☒ Type stainless Make JOHNSON					
Diameter		Slot/Gauze		Length Set	
3 in.		12		6 ft. 181 ft. 186 ft.	
Static Water Level					
6 ft.		land surface		Measure 12/17/2025	
Pumping Level (below land surface)					
10 ft.		3 hrs.		Pumping at 100 g.p.m.	
Wellhead Completion					
Pitless adapter manufacturer				Model BULLDOG	
☐ Casing Protection ☒ 12 in. above grade					
☐ At-grade (Environmental Wells and Borings ONLY)					
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified					
Material		Amount		From To	
bentonite		3 Sacks		6 ft. 50 ft.	
Nearest Known Source of Contamination					
150 feet		North Direction		Sewer Type	
Well disinfected upon completion? ☒ Yes ☐ No					
Pump ☐ Not Installed Date Installed 12/17/2025					
Manufacturer's name FLOWISE					
Model Number		P10S05		HP 0.5 Volt 230	
Length of drop pipe		20 ft		Capacity 10 g.p. Typ Submersible	
Abandoned					
Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No					
Variance					
Was a variance granted from the MDH for this well? ☐ Yes ☒ No					
Miscellaneous					
First Bedrock		Aquifer			
Last Strat		Depth to Bedrock ft			
Located by					
Locate Method					
System		UTM - NAD83, Zone 15, Meters		X Y	
Unique Number Verification				Input Date	
Angled Drill Hole					
Well Contractor					
Mattson Well Co.		1544		MATTSON, K	
Licensee Business		Lic. or Reg. No.		Name of Driller	