

894877

County Wright
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/04/2026
Update Date 05/04/2026
Received Date 01/30/2026

Well Name POLZIN, TRAVIS					Township 119	Range 28	Dir W	Section 10	Subsection ADD
Elevation					Elev. Method				
Address									
Well					14112 15TH ST SW COKATO MN 55321				
Contact					216 NORTH CASEY ST DARWIN MN 55324				
Stratigraphy Information									
Geological Material		From	To (ft.)	Color	Hardness				
CLAY		0	10	YELLOW					
CLAY + SAND		10	38	YELLOW					
CLAY + SAND		38	97	BLUE					
CLAY		97	206	BLUE					
SAND		206	214						
Well Depth 214 ft.									
Depth Completed 214 ft.									
Date Well Completed 12/23/2025									
Drill Method Non-specified Rotary					Drill Fluid Qwik gel				
Use domestic					Status Active				
Well Hydrofractured? Yes ☐ No ☒ From To									
Casing Type Single casing									
Joint Glued									
Drive Shoe? Yes ☐ No ☒ Above/Below									
Casing Diameter 4 in. To					Weight 208 ft. lbs./ft.			Hole Diameter 6.7 in. To 214 ft.	
Open Hole From ft. To ft.									
Screen? ☒ Type stainless Make JOHNSON									
Diameter		Slot/Gauze		Length		Set			
3 in.		12		6 ft.		208 ft.		214 ft.	
Static Water Level 16 ft. land surface Measure 12/23/2025									
Pumping Level (below land surface) 40 ft. 2 hrs. Pumping at 20 g.p.m.									
Wellhead Completion Pitless adapter manufacturer Model BULLDOG									
☐ Casing Protection ☒ 12 in. above grade									
☐ At-grade (Environmental Wells and Borings ONLY)									
Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified									
Material		Amount		From		To			
bentonite		3 Sacks		6 ft.		50 ft.			
Nearest Known Source of Contamination 54 feet East Direction Sewer Type									
Well disinfected upon completion? ☒ Yes ☐ No									
Pump ☐ Not Installed Date Installed 01/09/2026									
Manufacturer's name FLOWISE									
Model Number		P10S05		HP 0.5		Volt 230			
Length of drop pipe		60 ft		Capacity 10 g.p.		Typ Submersible			
Abandoned Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No									
Variance Was a variance granted from the MDH for this well? ☐ Yes ☒ No									
Miscellaneous First Bedrock Aquifer Last Strat Depth to Bedrock ft Located by Locate Method System UTM - NAD83, Zone 15, Meters X Y Unique Number Verification Input Date									
Angled Drill Hole									
Well Contractor Mattson Well Co. 1544 MATTSON, K Licensee Business Lic. or Reg. No. Name of Driller									
Remarks									