

895090

County Mille Lacs
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date02/12/2026
Update Date02/12/2026
Received Date01/12/2026

Well Name KN BUILDERS					Township 38	Range 26	Dir W	Section 20	Subsection DCC	Well Depth 45 ft.				Depth Completed 45 ft.				Date Well Completed 11/11/2025			
Elevation					Elev. Method					Drill Method Non-specified Rotary				Drill Fluid Bentonite							
Address										Use domestic				Status Active							
Well 15588 100TH AV MILACA MN 56353										Well Hydrofractured? Yes ☐ No ☒				From To							
Contact 15697 180TH ST MILACA MN 56353										Casing Type Single casing				Joint							
Stratigraphy Information										Drive Shoe? Yes ☐ No ☒				Above/Below							
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter				Weight				Hole Diameter							
CLAY ROCKS		0	20	BROWN	HARD	4 in. To 35 ft. 2.25 lbs./ft.				7.8 in. To 45 ft.											
SAND ROCKS		20	35	BROWN	MEDIUM																
AQUIFER		35	45	GRAY	SOFT																
Open Hole										From	ft.	To	ft.								
Screen? ☒		Type plastic		Make SAND SHARK																	
Diameter		Slot/Gauze		Length		Set															
4 in.		10		10 ft.		35 ft.		45 ft.													
Static Water Level																					
26 ft.		land surface		Measure		11/11/2025															
Pumping Level (below land surface)																					
30 ft.		1 hrs.		Pumping at		30 g.p.m.															
Wellhead Completion																					
Pitless adapter manufacturer										Model											
☐ Casing Protection										☐ 12 in. above grade											
☐ At-grade (Environmental Wells and Borings ONLY)																					
Grouting Information										Well Grouted? ☒ Yes ☐ No ☐ Not Specified											
Material				Amount				From		To											
bentonite				6 Sacks				ft.		35 ft.											
Nearest Known Source of Contamination																					
50 feet		Northwes		Direction		Septic tank/drain field		Type													
Well disinfected upon completion?										☒ Yes ☐ No											
Pump ☒		Not Installed		Date Installed																	
Manufacturer's name																					
Model Number				HP		Volt															
Length of drop pipe				ft		Capacity		g.p.		Typ											
Abandoned																					
Does property have any not in use and not sealed well(s)?										☐ Yes ☒ No											
Variance																					
Was a variance granted from the MDH for this well?										☐ Yes ☒ No											
Miscellaneous																					
First Bedrock				Aquifer																	
Last Strat				Depth to Bedrock		ft															
Located by																					
Locate Method																					
System				UTM - NAD83, Zone 15, Meters		X		Y													
Unique Number Verification				Input Date																	
Angled Drill Hole																					
Well Contractor																					
Bills Well Drilling, Inc.				2123		JOHNSON, M															
Licensee Business				Lic. or Reg. No.		Name of Driller															