

895139

County Beltrami
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 01/30/2026
Update Date 01/30/2026
Received Date 01/21/2026

Well Name MICHALICEK,					Township 149	Range 32	Dir W	Section 14	Subsection BAA	Well Depth 72 ft.		Depth Completed 72 ft.		Date Well Completed 01/12/2026							
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Bentonite									
Address										Use domestic		Status Active									
C/W 12112 BIRCHWOOD RD NE TENSTRIKE MN 56683										Well Hydrofractured?		Yes ☐		No ☒		From		To			
Stratigraphy Information										Casing Type Single casing		Joint									
Geological Material										Drive Shoe?		Yes ☐		No ☒		Above/Below					
CLAY										Casing Diameter		Weight		Hole Diameter							
CLAY										4 in. To		72 ft.		lbs./ft.		8 in. To		72 ft.			
CLAY/ SAND										50		60		GRAY		MEDIUM					
SAND										60		72		GRAY		SOFT					
										Open Hole		From		ft.		To		ft.			
										Screen? ☒		Type plastic		Make							
										Diameter		Slot/Gauze		Length		Set					
										4 in.		15		5 ft.		67 ft.		72 ft.			
										Static Water Level											
										6 ft.		land surface		Measure		01/12/2026					
										Pumping Level (below land surface)											
										ft.		hrs.		Pumping at		80		g.p.m.			
										Wellhead Completion											
										Pitless adapter manufacturer		AQUA SEAL		Model		4X1					
										☐ Casing Protection		☐ 12 in. above grade									
										☐ At-grade (Environmental Wells and Borings ONLY)											
										Grouting Information		Well Grouted?		☒ Yes		☐ No		☐ Not Specified			
										Material		Amount		From		To					
										other				65 ft.		72 ft.					
										bentonite				ft.		65 ft.					
										Nearest Known Source of Contamination											
										90 feet		West Direction		Septic tank/drain field		Type					
										Well disinfected upon completion?		☒ Yes		☐ No							
										Pump		☐ Not Installed		Date Installed							
										Manufacturer's name		GRUNDFOS									
										Model Number		SQ		HP		0.75		Volt		230	
										Length of drop pipe		50 ft		Capacity		10 g.p.		Typ		Submersible	
										Abandoned											
										Does property have any not in use and not sealed well(s)?		☐ Yes		☒ No							
										Variance											
										Was a variance granted from the MDH for this well?		☐ Yes		☒ No							
										Miscellaneous											
										First Bedrock				Aquifer							
										Last Strat				Depth to Bedrock		ft					
										Located by											
										Locate Method											
										System		UTM - NAD83, Zone 15, Meters		X		Y					
										Unique Number Verification				Input Date							
										Angled Drill Hole											
										Well Contractor											
										Reed and Reed Water Well		1854		REED, G							
										Licensee Business		Lic. or Reg. No.		Name of Driller							