

895288

County Sherburne
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/05/2026
Update Date 05/05/2026
Received Date 02/18/2026

Well Name NC	Township 35	Range 26	Dir Section W 31	Subsection AAC	Well Depth 60 ft.	Depth Completed 60 ft.	Date Well Completed 01/08/2026																																			
Elevation	Elev. Method				Drill Method Non-specified Rotary	Drill Fluid Bentonite																																				
Address					Use domestic	Status Active																																				
Well 13736 283RD AV NW ZIMMERMAN MN 55398					Well Hydrofractured? Yes ☐ No ☒ From To																																					
Contact 605 RUM RIVER DR N PRINCETON MN 55371					Casing Type Single casing Joint																																					
Stratigraphy Information					Drive Shoe? Yes ☐ No ☒ Above/Below																																					
<table><tr><td>Geological Material</td><td>From</td><td>To (ft.)</td><td>Color</td><td>Hardness</td></tr><tr><td>CLAY SAND</td><td>0</td><td>16</td><td>BROWN</td><td>MEDIUM</td></tr><tr><td>CLAY</td><td>16</td><td>30</td><td>BROWN</td><td>MEDIUM</td></tr><tr><td>SAND</td><td>30</td><td>50</td><td>BROWN</td><td>SOFT</td></tr><tr><td>AQUIFER</td><td>50</td><td>60</td><td>GRAY</td><td>SOFT</td></tr></table>					Geological Material	From	To (ft.)	Color	Hardness	CLAY SAND	0	16	BROWN	MEDIUM	CLAY	16	30	BROWN	MEDIUM	SAND	30	50	BROWN	SOFT	AQUIFER	50	60	GRAY	SOFT	<table><tr><td>Casing Diameter</td><td colspan="2">Weight</td><td colspan="2">Hole Diameter</td></tr><tr><td>4 in. To</td><td>50 ft.</td><td>2.25 lbs./ft.</td><td>7.8 in. To</td><td>60 ft.</td></tr></table>			Casing Diameter	Weight		Hole Diameter		4 in. To	50 ft.	2.25 lbs./ft.	7.8 in. To	60 ft.
Geological Material	From	To (ft.)	Color	Hardness																																						
CLAY SAND	0	16	BROWN	MEDIUM																																						
CLAY	16	30	BROWN	MEDIUM																																						
SAND	30	50	BROWN	SOFT																																						
AQUIFER	50	60	GRAY	SOFT																																						
Casing Diameter	Weight		Hole Diameter																																							
4 in. To	50 ft.	2.25 lbs./ft.	7.8 in. To	60 ft.																																						
					Open Hole From ft. To ft.																																					
					Screen? ☒ Type plastic Make JET STREAM																																					
					Diameter Slot/Gauze Length Set																																					
					4 in. 10 10 ft. 50 ft. 60 ft.																																					
					Static Water Level																																					
					29 ft. land surface Measure 01/08/2026																																					
					Pumping Level (below land surface)																																					
					50 ft. 1 hrs. Pumping at 50 g.p.m.																																					
					Wellhead Completion																																					
					Pitless adapter manufacturer Model																																					
					☐ Casing Protection ☐ 12 in. above grade																																					
					☐ At-grade (Environmental Wells and Borings ONLY)																																					
					Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified																																					
					Material Amount From To																																					
					bentonite 6 Sacks ft. 50 ft.																																					
					Nearest Known Source of Contamination																																					
					50 feet Southwes Direction Septic tank/drain field Type																																					
					Well disinfected upon completion? ☒ Yes ☐ No																																					
					Pump ☒ Not Installed Date Installed																																					
					Manufacturer's name																																					
					Model Number HP Volt																																					
					Length of drop pipe ft Capacity g.p. Typ																																					
					Abandoned																																					
					Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No																																					
					Variance																																					
					Was a variance granted from the MDH for this well? ☐ Yes ☒ No																																					
					Miscellaneous																																					
					First Bedrock Aquifer																																					
					Last Strat Depth to Bedrock ft																																					
					Located by																																					
					Locate Method																																					
					System UTM - NAD83, Zone 15, Meters X Y																																					
					Unique Number Verification Input Date																																					
					Angled Drill Hole																																					
					Well Contractor																																					
					Bills Well Drilling, Inc. 2123 GRAHAM, K																																					
					Licensee Business Lic. or Reg. No. Name of Driller																																					
Remarks																																										