

895496

County Otter Tail
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 04/29/2026
Received Date 11/23/2025

Well Name J.D;S LAKE					Township 137		Range 42		Dir Section W 4		Subsection ABD		Well Depth 60 ft.			Depth Completed 60 ft.			Date Well Completed 11/20/2025																		
Elevation					Elev. Method													Drill Method Non-specified Rotary			Drill Fluid Bentonite																
Address C/W 51750 PELICAN OT DR DETROIT LAKES MN															Use domestic			Status Active																			
Stratigraphy Information Geological Material From To (ft.) Color Hardness TOP SOIL 0 1 BLACK SOFT SAND 1 35 MEDIUM 35 60 GRAY															Well Hydrofractured?			Yes ☐		No ☒		From			To												
															Casing Type			Single casing						Joint													
															Drive Shoe?			Yes ☐		No ☒		Above/Below															
															Casing Diameter			Weight						Hole Diameter													
															4 in. To			52 ft. 1 lbs./ft.						6.7 in. To 60 ft.													
															Open Hole															From		ft.		To		ft.	
															Screen?			☒		Type		stainless		Make		JOHNSON											
															Diameter			Slot/Gauze		Length		Set															
															2 in.			10		8 ft.		52 ft.		60 ft.													
															Static Water Level															6 ft.		land surface		Measure		11/20/2025	
Pumping Level (below land surface)															51 ft.		1 hrs.		Pumping at		50 g.p.m.																
Wellhead Completion															Pitless adapter manufacturer						MONITOR		Model		SNAPPY												
															☐		Casing Protection		☒		12 in. above grade																
															☐		At-grade (Environmental Wells and Borings ONLY)																				
Grouting Information															Well Grouted?		☒		Yes		☐		No		☐		Not Specified										
															Material		Amount		From		To																
															other		4 Sacks				ft. 48		ft.														
Nearest Known Source of Contamination															100 feet		East Direction								Sewer Type												
															Well disinfected upon completion?						☒		Yes		☐		No										
Pump															☐		Not Installed		Date Installed		11/20/2025																
															Manufacturer's name						STA-RITE																
															Model Number		S10P4JP102		HP		1		Volt		230												
															Length of drop pipe		40 ft		Capacity		10 g.p.		Typ		Submersible												
Abandoned															Does property have any not in use and not sealed well(s)?										☐		Yes		☒		No						
Variance															Was a variance granted from the MDH for this well?										☐		Yes		☒		No						
Miscellaneous															First Bedrock						Aquifer																
															Last Strat						Depth to Bedrock						ft										
Remarks															Located by																						
															Locate Method																						
															System		UTM - NAD83, Zone 15, Meters						X		Y												
															Unique Number Verification												Input Date										
Angled Drill Hole																																					
Well Contractor															Elsner Well Drilling, Inc.						1374		MONROE, W														
															Licensee Business						Lic. or Reg. No.		Name of Driller														