

895570

County Wadena
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date 05/11/2026
Update Date 05/11/2026
Received Date 01/26/2026

Well Name HOIST	Township 136	Range 33	Dir W	Section 25	Subsection BBA	Well Depth 84 ft.	Depth Completed 84 ft.	Date Well Completed 11/17/2025
Elevation	Elev. Method					Drill Method Non-specified Rotary	Drill Fluid Bentonite	
Address						Use domestic	Status Active	
C/W 27379 240TH ST VERNDALE MN 56487						Well Hydrofractured? Yes ☐ No ☒ From To		
Contact 28877 TODD LINE RD STAPLES MN 56479						Casing Type Single casing Joint		
Stratigraphy Information						Drive Shoe? Yes ☐ No ☒ Above/Below		
Geological Material		From	To (ft.)	Color	Hardness	Casing Diameter Weight Hole Diameter		
SAND		0	9	BROWN	MEDIUM	4 in. To 80 ft. 200 lbs./ft. 7.8 in. To 84 ft.		
CLAY		9	34	BROWN	MEDIUM			
CLAY		34	76	GRAY	MEDIUM			
SAND		76	84	BROWN	MEDIUM			
						Open Hole From ft. To ft.		
						Screen? ☒ Type stainless Make JOHNSON		
						Diameter Slot/Gauze Length Set		
						2 in. 12 4 ft. 80 ft. 84 ft.		
						Static Water Level		
						25 ft. land surface Measure 11/17/2025		
						Pumping Level (below land surface)		
						61 ft. 1 hrs. Pumping at 15 g.p.m.		
						Wellhead Completion		
						Pitless adapter manufacturer BAKER Model BULLDOG		
						☐ Casing Protection ☒ 12 in. above grade		
						☐ At-grade (Environmental Wells and Borings ONLY)		
						Grouting Information Well Grouted? ☒ Yes ☐ No ☐ Not Specified		
						Material Amount From To		
						bentonite 5 Sacks ft. 60 ft.		
						Nearest Known Source of Contamination		
						51 feet West Direction Septic tank/drain field Type		
						Well disinfected upon completion? ☒ Yes ☐ No		
						Pump ☒ Not Installed Date Installed		
						Manufacturer's name		
						Model Number HP Volt		
						Length of drop pipe ft Capacity g.p. Typ		
						Abandoned		
						Does property have any not in use and not sealed well(s)? ☐ Yes ☒ No		
						Variance		
						Was a variance granted from the MDH for this well? ☐ Yes ☒ No		
						Miscellaneous		
						First Bedrock Aquifer		
						Last Strat Depth to Bedrock ft		
						Located by		
						Locate Method		
						System UTM - NAD83, Zone 15, Meters X Y		
						Unique Number Verification Input Date		
						Angled Drill Hole		
						Well Contractor		
						Blue Water Wells LP 2140 KLINE, M		
						Licensee Business Lic. or Reg. No. Name of Driller		