

895901

County Redwood
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 05/07/2026
Received Date 01/16/2026

Well Name YANG, CHOR					Township 109	Range 38	Dir W	Section 15	Subsection CDA	Well Depth 216 ft.		Depth Completed 216 ft.		Date Well Completed 11/20/2025					
Elevation					Elev. Method					Drill Method Non-specified Rotary		Drill Fluid Bentonite							
Address										Use domestic		Status Active							
C/W 19395 130TH ST WALNUT GROVE MN 56180										Well Hydrofractured?		Yes ☐		No ☐		From		To	
Stratigraphy Information										Casing Type Single casing		Joint							
Geological Material										Drive Shoe?		Yes ☐		No ☐		Above/Below			
Geological Material										Casing Diameter		Weight		Hole Diameter					
TOPSOIL										5 in. To		207 ft.		lbs./ft.		7.9 in. To		209 ft.	
CLAY																4.2 in. To		216 ft.	
GUMMY CLAY																			
SAND - FINE																			
SANDY CLAY																			
SANDSTONE -																			
										Open Hole		From		ft.		To		ft.	
										Screen? ☒		Type stainless		Make JOHNSON					
										Diameter		Slot/Gauze		Length		Set			
										2 in.		12		10 ft.		206 ft.		216 ft.	
										Static Water Level									
										1 ft.		land surface		Measure		11/21/2025			
										Pumping Level (below land surface)									
										92 ft.		hrs.		Pumping at		12 g.p.m.			
										Wellhead Completion									
										Pitless adapter manufacturer		MONITOR		Model					
										☐ Casing Protection		☐ 12 in. above grade							
										☐ At-grade (Environmental Wells and Borings ONLY)									
										Grouting Information		Well Grouted?		☒ Yes		☐ No		☐ Not Specified	
										Material		Amount		From		To			
										neat cement		17 Sacks				ft. 196 ft.			
										Nearest Known Source of Contamination									
										52 feet		South Direction				Other Type			
										Well disinfected upon completion?		☐ Yes		☐ No					
										Pump ☐ Not Installed		Date Installed		11/21/2025					
										Manufacturer's name		FRANKLIN							
										Model Number		10FS07S4		HP 0.75		Volt 230			
										Length of drop pipe		120 ft		Capacity 10 g.p.		Typ Submersible			
										Abandoned									
										Does property have any not in use and not sealed well(s)?		☐ Yes		☐ No					
										Variance									
										Was a variance granted from the MDH for this well?		☐ Yes		☒ No					
										Miscellaneous									
										First Bedrock				Aquifer					
										Last Strat				Depth to Bedrock				ft	
										Located by									
										Locate Method									
										System		UTM - NAD83, Zone 15, Meters		X		Y			
										Unique Number Verification						Input Date			
										Angled Drill Hole									
										Well Contractor									
										Steffl Drilling and Pump, Inc.		1551		JONES, W.					
										Licensee Business		Lic. or Reg. No.				Name of Driller			