

896299

County Beltrami
Quad
Quad ID

MINNESOTA DEPARTMENT OF HEALTH
WELL AND BORING REPORT
Minnesota Statutes Chapter 1031

Entry Date
Update Date 01/20/2026
Received Date 01/05/2026

Well Name SWENSON,					Township 147	Range 34	Dir W	Section 20	Subsection DAB	Well Depth 85 ft.			Depth Completed 85 ft.			Date Well Completed 10/30/2025		
Elevation					Elev. Method					Drill Method Non-specified Rotary			Drill Fluid Bentonite					
Address										Use domestic			Status Active					
Well WHITESAGE DR NW BEMIDJI MN 56601										Well Hydrofractured? Yes ☐ No ☒			From To					
Contact 1101 WILTON HILL RD BEMIDJI MN 56601										Casing Type Single casing			Joint					
Stratigraphy Information										Drive Shoe? Yes ☐ No ☐			Above/Below					
Geological Material					From	To (ft.)	Color	Hardness		Casing Diameter 4 in. To 80 ft.			Weight lbs./ft.		Hole Diameter 7.8 in. To 20 ft. 6.7 in. To 85 ft.			
SANDY CLAY					0	12	BROWN	MEDIUM										
CLAY					12	23	BROWN	MEDIUM										
SANDY CLAY					23	60	GRAY	MEDIUM										
SAND					60	85	BRN/GRY	SOFT										
										Open Hole			From	ft.	To	ft.		
										Screen? ☒			Type stainless		Make JOHNSON			
										Diameter		Slot/Gauze	Length	Set				
										2 in.	12	5 ft.	80 ft.	85 ft.				
										Static Water Level								
										18 ft.	land surface		Measure	10/30/2025				
										Pumping Level (below land surface)								
										40 ft.	1 hrs.	Pumping at	30	g.p.m.				
										Wellhead Completion								
										Pitless adapter manufacturer		MERRILL		Model MCK410				
										☐ Casing Protection		☐ 12 in. above grade						
										☐ At-grade (Environmental Wells and Borings ONLY)								
										Grouting Information			Well Grouted?		☒ Yes	☐ No	☐ Not Specified	
										Material		Amount		From	To			
										other		4	Sacks	ft.	50	ft.		
										Nearest Known Source of Contamination								
										feet		Direction				Type		
										Well disinfected upon completion?			☒ Yes	☐ No				
										Pump ☐ Not Installed			Date Installed		11/03/2025			
										Manufacturer's name			STA-RITE					
										Model Number		K-SERIES	HP	0.5	Volt	230		
										Length of drop pipe		50 ft	Capacity	10 g.p.	Typ	Submersible		
										Abandoned								
										Does property have any not in use and not sealed well(s)?			☐ Yes	☒ No				
										Variance								
										Was a variance granted from the MDH for this well?			☐ Yes	☒ No				
										Miscellaneous								
										First Bedrock		Aquifer						
										Last Strat		Depth to Bedrock		ft				
										Located by								
										Locate Method								
										System		UTM - NAD83, Zone 15, Meters		X	Y			
										Unique Number Verification		Input Date						
										Angled Drill Hole								
										Well Contractor								
										Gracco Well Drilling		2960		FELL, B				
										Licensee Business		Lic. or Reg. No.		Name of Driller				
Remarks																		